CITY OF CORVALLIS FIRE DEPARTMENT

INSPECTION REPORT

OSU BEAVER BEGINNINGS CHILD CARE CENTER, 1262 SW ADAMS AVE, BLDG OSU BEAVER BEGINNINGS CHILD CARE CENTER, CORVALLIS OR 97331



DETAILS

Inspection Date: 11/22/2021 | Inspection Type: Operations B, M, and R-2 | Inspection Number: 60484 | Shift: Prevention | Station: Corvallis Station 2 | Unit: W171 | Lead Inspector: JASON DENNIS | Other Inspectors: N/A

STATUS	CODE	DESCRIPTION
FAIL	Oregon 607.3.3.1d - Commercial Hood Cleaning - 12 month frequency	Low-volume cooking operations such as places of religious worship, seasonal businesses and senior centers
	12 monar n equency	Inspector: JASON DENNIS - Comments: Type 2 hood kitchen dishwasher



REINSPECTION DATE

12/22/2021

CONTACT SIGNATURE

Chris Riggan

Signed on: 11/22/2021 @ 10:43

INSPECTOR SIGNATURE

JASON DENNIS

Signed on: 11/22/2021 @ 10:43

QUESTIONS ABOUT YOUR INSPECTION?

JASON DENNIS jason.dennis@corvallisoregon.gov No phone number available