

Building Manager: [William Callender, bill.callender@oregonstate.edu](mailto:bill.callender@oregonstate.edu)  
 Assessment Date: 4/4/2022  
 Assessment Number: **10564**  
 Location: Dixon Recreation Center Entire  
 Reinspection date:

A joint fire safety inspection of the facility listed above was performed by the Environmental Health & Safety - Fire and Life Safety and the Corvallis Fire Department. These fire safety deficiencies could result in a fire or jeopardize the safety of those occupying the facility. Please see that these items are corrected immediately and no later than the scheduled reinspection date noted with this report. If you have any questions regarding this inspection, please email Brian Lilley (EH&S - Fire and Life Safety) at [brian.lilley@oregonstate.edu](mailto:brian.lilley@oregonstate.edu).

**Note: Deficiencies that are bold and underlined remain uncorrected from the last fire/life safety inspection(s) and should be corrected immediately.**

\* Annotates a deficiency identified by the Corvallis Fire Department.

Indicated on the report are items which should be corrected by the Departments (DEPT) that occupy this building, Facilities Services (FS), Environmental Health & Safety (EHS), and Recycling (RECY). Please forward a copy of this report to the responsible group(s) and begin corrective action so that all deficiencies have been corrected prior to the reinspection date. If assistance is required from Facilities Services to estimate or correct an item assigned to a Department, contact the Work Coordination Center at ext. 7-2969.

**Facilities Services Priority Codes:**

**Priority 1:** items are considered immediate safety hazards and should be corrected within 48 hours of notification if possible. If repairs cannot be made immediately, temporary measures may be taken.

**Priority 2:** items should be corrected within the five-week period before the scheduled reinspections.

**Priority 3:** items are long term fixes that should be either added to an ongoing work list or to the capital improvement list for campus upgrades.

**Comments:**

<b>Priority code</b>	<b>Standard in need of attention</b>	<b>Reg.Reference</b>	<b>Location</b>	<b>Resp</b>	<b>Observations &amp; Recommendations</b>	<b><a href="#">Date Corrected</a></b>
3	Fire department connections (FDC) must be visible, identified, accessible, and must be tested and maintained. Partial building coverage shall be indicated.	2019 OFC 912	FDC:Outside	DEPT	Provide sign on FDC.	

<b>Priority code</b>	<b>Standard in need of attention</b>	<b>Reg.Reference</b>	<b>Location</b>	<b>Resp</b>	<b>Observations &amp; Recommendations</b>	<b><a href="#">Date Corrected</a></b>
----------------------	--------------------------------------	----------------------	-----------------	-------------	---	---------------------------------------

2	Exit and exit access doors shall be marked by an approved exit sign readily visible from any direction of egress travel.	2019 OFC 1013.1	MP2:inside	DEPT	Exit sign in multipurpose room 2 is not visible and blocked by speaker. Relocate speaker so exit sign is visible.	
---	--	-----------------	------------	------	---	--



MP2

2	Emergency lighting shall be maintained.	2019 OFC 1031.10	Various:Throughout	DEPT	Exit sign lights out in spaces:  Lower gym court 2 (bug-eye lights not working properly)  Second floor east corridor outside room 250A (exit sign not illuminating when test button pressed)  Track south side (bug-eye lights not working)	
---	---	------------------	--------------------	------	---	--

Priority code	Standard in need of attention	Reg.Reference	Location	Resp	Observations & Recommendations	<a href="#">Date Corrected</a>
2	Illumination shall be provided in the means of egress at all times.	2019 OFC 1008.1	Bike Studio:Room 126	DEPT	Provide self-illuminating tape aisle on floor from back of room to exit door in bike studio 126.	



Bike Studio 126