

# CITY OF CORVALLIS FIRE DEPARTMENT

## INSPECTION REPORT

OSU FAIRPLAY LAB, 3720 NE CONIFER BLVD, BLDG OSU FAIRPLAY LAB, CORVALLIS OR 97330



### DETAILS

Inspection Date: 08/24/2022 | Inspection Type: Fire & Life Safety Inspection | Inspection Number: 60937 | Shift: Prevention | Station: Corvallis Station 3 | Unit: W171 | Lead Inspector: JASON DENNIS | Other Inspectors: N/A

| STATUS | CODE | DESCRIPTION |
|--------|------|-------------|
|--------|------|-------------|

|             |  |  |
|-------------|--|--|
| <b>FAIL</b> | Oregon 5303.5.3 - Securing compressed gas containers, cylinders and tanks. | Compressed gas containers, cylinders and tanks shall be secured to prevent falling caused by contact, vibration or seismic activity. Securing of compressed gas containers, cylinders and tanks shall be by one of the following methods: 1. Securing containers, cylinders and tanks to a fixed object with one or more restraints. 2. Securing containers, cylinders and tanks on a cart or other mobile device designed for the movement of compressed gas containers, cylinders or tanks. 3. Nesting of compressed gas containers, cylinders and tanks at container filling or servicing facilities or in sellers' warehouses not open to the public. Nesting shall be allowed provided that the nested containers, cylinders or tanks, if dislodged, do not obstruct the required means of egress. 4. Securing of compressed gas containers, cylinders and tanks to or within a rack, framework, cabinet or similar assembly designed for such use. Exception: Compressed gas containers, cylinders and tanks in the process of examination, filling, transport or servicing. |
|-------------|--|--|

Inspector: JASON DENNIS - Comments: larger than 5 gallon propane tanks

|             |                               |  |
|-------------|-------------------------------|--|
| <b>FAIL</b> | Oregon 604.5.1 - Power supply | Extension cords shall be plugged directly into an approved receptacle, power tap or multiplug adapter and, except for approved multiplug extension cords, shall serve only one portable appliance. |
|-------------|-------------------------------|--|



Inspector: JASON DENNIS - Comments: block house kitchen

|             |                             |  |
|-------------|-----------------------------|--|
| <b>FAIL</b> | Oregon 604.6 - Cover plates | Open junction boxes and open-wiring splices shall be prohibited. Approved covers shall be provided for all switch and electrical outlet boxes. |
|-------------|-----------------------------|--|

Inspector: JASON DENNIS - Comments: block house kitchen

**REINSPECTION DATE**


10/23/2022

**FEE**

Invoice Date: N/A | Inspection Fee: N/A | Date Paid: N/A | Amount Paid: N/A | Invoice Number: N/A | Check Number: N/A | Transaction Number: N/A

**CONTACT SIGNATURE**

Brian Lilley  
Signed on: 08/24/2022 @ 16:38



**INSPECTOR SIGNATURE**

JASON DENNIS  
Signed on: 08/24/2022 @ 16:38



**QUESTIONS ABOUT YOUR INSPECTION?**

JASON DENNIS  
jason.dennis@corvallisoregon.gov  
No phone number available