

Building Manager: [Anthony Conrath, anthony.conrath@oregonstate.edu](mailto:anthony.conrath@oregonstate.edu)
 Assessment Date: 2/15/2021
 Assessment Number: **9969**
 Location: Goss Stadium Entire
 Reinspection date: 3/31/2021

A joint fire safety inspection of the facility listed above was performed by the Environmental Health & Safety - Fire and Life Safety and the Corvallis Fire Department. These fire safety deficiencies could result in a fire or jeopardize the safety of those occupying the facility. Please see that these items are corrected immediately and no later than the scheduled reinspection date noted with this report. If you have any questions regarding this inspection, please email Brian Lilley (EH&S - Fire and Life Safety) at brian.lilley@oregonstate.edu.

Note: Deficiencies that are bold and underlined remain uncorrected from the last fire/life safety inspection(s) and should be corrected immediately.

* Annotates a deficiency identified by the Corvallis Fire Department.

Indicated on the report are items which should be corrected by the Departments (DEPT) that occupy this building, Facilities Services (FS), Environmental Health & Safety (EHS), and Recycling (RECY). Please forward a copy of this report to the responsible group(s) and begin corrective action so that all deficiencies have been corrected prior to the reinspection date. If assistance is required from Facilities Services to estimate or correct an item assigned to a Department, contact the Work Coordination Center at ext. 7-2969.

Facilities Services Priority Codes:

Priority 1: items are considered immediate safety hazards and should be corrected within 48 hours of notification if possible. If repairs cannot be made immediately, temporary measures may be taken.

Priority 2: items should be corrected within the five-week period before the scheduled reinspections.

Priority 3: items are long term fixes that should be either added to an ongoing work list or to the capital improvement list for campus upgrades.

Comments:

Priority code	Standard in need of attention	Reg.Reference	Location	Resp	Observations & Recommendations	Date Corrected
1	Where access to or within a structure is necessary, a key box may be authorized by the fire code official.	2019 OFC 506.1	Throughout..	KEY	Provide keys for Knox Box.	
1	Clearance between ignition sources and combustible materials shall be maintained.	2019 OFC 305.1	Player's Lounge:inside	DEPT	Immediately maintain 36 inches of clearance in front of wall heater by wall of jerseys.	
1	Lint and refuse shall be removed from dryer traps daily.	2019 OFC 2105.1.5.3	Laundry:inside	DEPT	Clean and maintain lint trap in clothes dryer.	

Priority code	Standard in need of attention	Reg.Reference	Location	Resp	Observations & Recommendations	Date Corrected
1	A working space of not less than 36 inches in front of electrical service equipment shall be maintained. Storage of materials shall not be located within this space.	2019 OFC 604.3.1	Throughout:inside	DEPT	Maintain clearance in front of electrical panels in rooms: A109C 160 172	
2	Extension cords and flexible cords shall not be a substitute for permanent wiring.	2019 OFC 604.5	SOFTBALL:Hitting Room	DEPT DEPT	Discontinue plugging extension cord into computer.	3/25/2021
1	Extension cords and flexible cords shall not be a substitute for permanent wiring.	2019 OFC 604.5	Throughout:inside	DEPT DEPT	Discontinue plugging extension cords into: Pitching machines Player's lounge equipment	
1	Storage of materials in buildings shall be orderly and stacks shall be stable.	2019 OFC 315.3	AS101:inside	DEPT	Maintain orderly storage by placing tape on floor indicating where items are to stored or remove items near door.	
1	Additional Findings:		SOFTBALL:Througho ut	DEPT FS DEPT/FS	Immediately fill out and submit permit for tents at soccer site. https://www.corvallisoregon.gov/fire/page/fire-permits	
2	Additional Findings:		Throughout:.	DEPT FS DEPT/FS	Replace ceiling tiles in rooms: A105 111	
1	Additional Findings:		110:inside	DEPT FS DEPT/FS	Maintain clearance around fire sprinkler riser - 2019 OFC 901.6.1	