

# CITY OF CORVALLIS FIRE DEPARTMENT

## INSPECTION REPORT

OSU GYMNASTICS TRAINING FACILITY, 4100 SW RESEARCH WAY, BLDG OSU GYMNASTICS  
BUILDING - STE D, CORVALLIS OR 97333



### DETAILS

Inspection Date: 12/15/2021 | Inspection Type: Operations B, M, and R-2 | Inspection Number: 60518 | Shift: Prevention | Station: Corvallis Station 2 | Unit: W171 | Lead Inspector: JASON DENNIS | Other Inspectors: N/A

STATUS	CODE	DESCRIPTION
--------	------	-------------

FAIL	Oregon 403.8.3.4 - Keys	Keys necessary for unlocking doors installed in a means of egress shall be individually identifiable by both touch and sight.
------	-------------------------	---



Inspector: JASON DENNIS - Comments: Need updated keys for all doors

FAIL	Oregon 610.1 - Clothes Dryer Lint Accumulation	Clothes dryers shall be frequently cleaned to maintain the lint trap, mechanical and heating components free from excessive accumulations of lint.
------	--	--

Inspector: JASON DENNIS - Comments: Provide documentation of cleaning schedule for dryer ducting

### REINSPECTION DATE

01/14/2022

### CONTACT SIGNATURE

Brian Lilley  
Signed on: 12/15/2021 @ 14:21

*EMAIL*

**INSPECTOR SIGNATURE**

JASON DENNIS  
Signed on: 12/15/2021 @ 14:21

A handwritten signature in black ink, appearing to be 'JD', is written over a horizontal line.

**QUESTIONS ABOUT YOUR INSPECTION?**

JASON DENNIS  
jason.dennis@corvallisoregon.gov  
No phone number available