

## NOTICE OF FIRE SAFETY INSPECTION OREGON STATE UNIVERSITY

Facility Inspected: Physical Plant Heating Plant  
 Inspection Date: 07/15/19 10:40 AM  
 Reinspect Date:

A fire safety inspection of the facility listed above was performed by the EH&S Fire and Life Safety Department. These fire safety deficiencies could result in a fire or jeopardize the safety of those occupying the facility. Please see that these items are corrected immediately. If you have any questions regarding this inspection, please email me. Thank you for your cooperation and support for fire safety. Jim Patton, Fire Safety Officer, jim.patton@oregonstate.edu

**Note: Deficiencies that are bold and underlined remain uncorrected from the last fire/life safety inspection(s) and should be corrected immediately.**

*\* Annotates a deficiency identified by OSU Environmental health and safety Department. Direct any questions regarding these items to that office (737-2273).*

*Indicated on the report are items which should be correct by the Departments (DEPT) that occupy this building, Facilities Services (FS), Environmental Health and Safety (EHS), and Recycling (RECY). Please forward a copy of this report to the responsible group(s) and begin corrective action to be completed no later than the reinspection date.*

**Facilities Services Priority Codes:**

**Priority 1:** (p1) items are considered immediate safety hazards and should be corrected within 48 hours of notification if possible. If repairs cannot be made immediately, temporary measures may be taken.

**Priority 2:** (p2) items should be corrected within the five-week period before the scheduled reinspections.

**Priority 3:** (p3) items are long term fixes that should be either added to an ongoing work list (such as annual testing of building sprinkler systems) or to the capital improvement list for campus upgrades.

*The due date is listed at the top of this page. If you have any questions, require additional information, or feel the items have been improperly assigned, feel free to contact Jim Patton (Fire and Life Safety) at jim.patton@oregonstate.edu. If assistance is required from Facilities Services to estimate or correct an item assigned to a Department, contact the Work Coordination Center at ext. 7-2969. MS Excel format is available upon request.*

Completed	Priority	Responsible Party	Location	Description	Code Reference	Notes
	2	Department	Near Weight Room	Label all chemical containers (1 gallon and larger) as to plain language contents & associated hazard. *All containers should be labeled.	CFC 2703.5.1	Label large square plastic containers as to contents
	2	Department	Small Welding Room	Discontinue the use of non fuse protected extension cords in place of permanent wiring. Fuse protected power strips are acceptable.	"CFC 605.4, 605.5"	Yellow cord to (compressor?)
	2	EH&S	Near exterior Diesel tank	Extinguishers shall be tagged and inspected annually. Recharge every 6 years. Hydrotest every 12 years.	"CFC 906.2, NFPA 10"	
	2	Department	Near 106A	Secure compressed gas cylinders.	CFC 3003.3.3	
	2	Department	Near 106	Label all chemical containers (1 gallon and larger) as to plain language contents & associated hazard. *All containers should be labeled.	CFC 2703.5.1	remove empty 55 gallon drums or label EMPTY
	1	Department	Right of 106	"Extinguishers shall be visible or signed, easily accessible, mounted with the bottom not less than 4 inches nor the top more than 4 feet above the floor."	"CFC 906.9, NFPA 10, ADA"	
	2	Department	Near Main Entry	Combustible recycling containers shall not be placed in exitways. Containers may be placed in non hazardous rooms.	CFC 319.5	Remove green recycling bins or relocate away from exit and exitways and keep lids closed.
	2	Department	Throughout	Reduce quantity of combustible debris in building. Ensure storage height doesn't exceed 12 feet. Minimize storage arrays to a minimum. Keep combustible storage away from sources of ignition to include electrical and heat producing.		