

Building Manager: [Ruth Milston-Clements, milstonr@science.oregonstate.edu](mailto:milstonr@science.oregonstate.edu)  
 Assessment Date: 7/15/2021  
 Assessment Number: **10207**  
 Location: John L. Fryer Aquatic Animal Health Lab Entire  
 Reinspection date: 8/31/2021

A joint fire safety inspection of the facility listed above was performed by the Environmental Health & Safety - Fire and Life Safety and the Corvallis Fire Department. These fire safety deficiencies could result in a fire or jeopardize the safety of those occupying the facility. Please see that these items are corrected immediately and no later than the scheduled reinspection date noted with this report. If you have any questions regarding this inspection, please email Brian Lilley (EH&S - Fire and Life Safety) at [brian.lilley@oregonstate.edu](mailto:brian.lilley@oregonstate.edu).

**Note: Deficiencies that are bold and underlined remain uncorrected from the last fire/life safety inspection(s) and should be corrected immediately.**

\* Annotates a deficiency identified by the Corvallis Fire Department.

Indicated on the report are items which should be corrected by the Departments (DEPT) that occupy this building, Facilities Services (FS), Environmental Health & Safety (EHS), and Recycling (RECY). Please forward a copy of this report to the responsible group(s) and begin corrective action so that all deficiencies have been corrected prior to the reinspection date. If assistance is required from Facilities Services to estimate or correct an item assigned to a Department, contact the Work Coordination Center at ext. 7-2969.

**Facilities Services Priority Codes:**

**Priority 1:** items are considered immediate safety hazards and should be corrected within 48 hours of notification if possible. If repairs cannot be made immediately, temporary measures may be taken.

**Priority 2:** items should be corrected within the five-week period before the scheduled reinspections.

**Priority 3:** items are long term fixes that should be either added to an ongoing work list or to the capital improvement list for campus upgrades.

**Comments:**

Priority code	Standard in need of attention	Reg.Reference	Location	Resp	Observations & Recommendations	Date Corrected
2	Door operating devices shall not require tight grasping, tight pinching or twisting of the wrist to operate.	2019 OFC 1010.1.9.1	Various:exit	FS	Change door hardware to exits from knob to lever-style handles:  South Exit Door (From Tank Room)  North Exit Door (From Hallway)	
2	Fire doors shall close from the full-open position and latch automatically.	2019 OFC 705.2.4	0104A:entrance	DEPT	Evaluation of door needed from lab to tank area. Door is designed and installed per fire door regulations and is NOT to be held open.	
2	Approved covers shall be provided for all switch and electrical outlet boxes.	2019 OFC 604.6	101:Mechanical	FS	Provide cover plates for 4 open junction boxes.	

<b>Priority code</b>	<b>Standard in need of attention</b>	<b>Reg.Reference</b>	<b>Location</b>	<b>Resp</b>	<b>Observations &amp; Recommendations</b>	<b><a href="#">Date Corrected</a></b>
2	Extension cords and flexible cords shall not be a substitute for permanent wiring.	2019 OFC 604.5	0110:inside	DEPT	Replace/remove extension cord to mini fridge with relocatable power tap or plug directly into wall receptacle.	