

NOTICE OF FIRE SAFETY INSPECTION OREGON STATE UNIVERSITY



Facility Inspected: HP CORVALLIS LEASE MBI

Inspection Date: 06/12/2014

Reinspect Date/Time: 07/21/2014 @ 1:30 pm

A fire safety inspection of the facility listed above was performed by the Corvallis Fire Prevention Bureau. These fire safety deficiencies could result in a fire or jeopardize the safety of those occupying the facility. Please see that these items are corrected immediately. If you have any questions regarding this inspection, please phone me at 737-3066. Thank you for your cooperation and support for fire safety. Jim Patton, Fire Prevention Officer, jim.patton@oregonstate.edu

Note: Deficiencies that are bold and underlined remain uncorrected from the last fire/life safety inspection(s) and should be corrected immediately.

** Annotates a deficiency identified by OSU Environmental Health and Safety Department. Direct any questions regarding these items to that office (737-2273).*

Indicated on the report are items which should be correct by the Departments (DEPT) that occupy this building, Facilities Services (FS), Environmental Health and Safety (EHS), and Recycling (RECY). Please forward a copy of this report to the responsible group(s) and begin corrective action to be completed no later than the reinspection date.

Facilities Services Priority Codes:

Priority 1: (p1) items are considered immediate safety hazards and should be corrected within 48 hours of notification if possible. If repairs cannot be made immediately, temporary measures may be taken.

Priority 2: (p2) items should be corrected within the five-week period before the scheduled reinspections.

Priority 3: (p3) items are long term fixes that should be either added to an ongoing work list (such as annual testing of building sprinkler systems) or to the capital improvement list for campus upgrades.

The due date is listed at the top of this page. If you have any questions, require additional information, or feel the items have been improperly assigned, feel free to contact Jim Patton (Corvallis Fire Department) at 737-3066. If assistance is required from Facilities Services to estimate or correct an item assigned to a Department, contact the Work Coordination Center at ext. 7-2969. MS Excel format is available upon request.

Completed?	Priority	Responsible Party	Location	Description	Code Reference	Notes
[]	2	DEPT	All Labs	Laboratory Safety Quick Reference Guide posted in each lab area. (These can be obtained from EH&S)	OSHA, Division 2 requirement, http://oregonstate.edu/ehs/sd0081	Ensure guides are mounted in every lab/area where chemicals are handled.
[]	2	DEPT	Room 1074	Discontinue the use of non fuse protected extension cords in place of permanent wiring. Fuse protected power strips are acceptable.	CFC 605.4, 605.5	
[]	2	DEPT	Room 1080	Discontinue the use of non fuse protected extension cords in place of permanent wiring. Fuse protected power strips are acceptable.	CFC 605.4, 605.5	
[]	2	DEPT	Room 1084	Discontinue the use of non fuse protected extension cords in place of permanent wiring. Fuse protected power strips are acceptable.	CFC 605.4, 605.5	
[]	2	DEPT	Room 1086	Discontinue practice of storing breakable chemical containers on floor.	CFC 2703.9.2	
[]	2	DEPT	Room 1086	Replace protective caps on all high pressure cylinders not actively in use.	CFC 3003.4	

Completed?	Priority	Responsible Party	Location	Description	Code Reference	Notes
[]	2	DEPT	Room 1000	Discontinue the use of non fuse protected extension cords in place of permanent wiring. Fuse protected power strips are acceptable.	CFC 605.4, 605.5	
[]	2	DEPT	Room 1000	Plug power strips directly into outlet. Do not chain one to another.	CFC 605.4.2	
[]	2	DEPT	Room 1006	Discontinue the use of non fuse protected extension cords in place of permanent wiring. Fuse protected power strips are acceptable.	CFC 605.4, 605.5	
[]	2	DEPT	Room 1014	Install or update hazard placard outside of lab with EH&S approved placard to identify associated hazards and emergency contact information.	NFPA 45, Chpt. 13.1.1, http://oregonstate.edu/ehs/LabHazSign	
[]	2	DEPT	Knox Box	Knox box shall be provided for buildings with fire alarms or sprinkler systems.	CFC 506.1	Provide copy of fire alarm panel key for Knox Box
[]	2	DEPT	Near 1078	Provide warning signs on containers, cabinets, and rooms.	CFC 3403.5	Label area bear empty drums "EMPTY DRUMS"
[]	2	DEPT	Near 1084	Plug power strips directly into outlet. Do not chain one to another.	CFC 605.4.2	

Completed?	Priority	Responsible Party	Location	Description	Code Reference	Notes
[]	2	DEPT	Near 1084	Excessive, outdated or spoiling chemical materials shall be scheduled for pick up and proper disposal.	Ref. NFPA 45, Chpt. 9, http://oregonstate.edu/ehs/waste	Many loose chemical containers. Discard those no longer needed, store others in approved cabinets or shelves.
[]	2	DEPT	Near Column E-6	Excessive, outdated or spoiling chemical materials shall be scheduled for pick up and proper disposal.	Ref. NFPA 45, Chpt. 9, http://oregonstate.edu/ehs/waste	Store away chemicals or dispose of properly.
[]	2	DEPT	Near Column E-6	Discontinue the use of non fuse protected extension cords in place of permanent wiring. Fuse protected power strips are acceptable.	CFC 605.4, 605.5	
[]	2	DEPT	Near Column E-6	Label all chemical containers (1 gallon and larger) as to plain language contents & associated hazard. *All containers should be labeled.	CFC 2703.5.1, http://oregonstate.edu/ehs/sites/default/files/pdf/si/chemical_storage_guidelines_si030.pdf	