

## Fire and Life Safety Report

Building Manager: [William Callender, bill.callender@oregonstate.edu](mailto:bill.callender@oregonstate.edu)  
 Assessment Date: 12/15/2020  
 Assessment Number: **9940**  
 Location: McAlexander Field House Entire  
 Reinspection date: 1/27/2021

A joint fire safety inspection of the facility listed above was performed by the Environmental Health & Safety - Fire and Life Safety and the Corvallis Fire Department. These fire safety deficiencies could result in a fire or jeopardize the safety of those occupying the facility. Please see that these items are corrected immediately and no later than the scheduled reinspection date noted with this report. If you have any questions regarding this inspection, please email Brian Lilley (EH&S - Fire and Life Safety) at [brian.lilley@oregonstate.edu](mailto:brian.lilley@oregonstate.edu).

**Note: Deficiencies that are bold and underlined remain uncorrected from the last fire/life safety inspection(s) and should be corrected immediately.**

\* Annotates a deficiency identified by the Corvallis Fire Department.

Indicated on the report are items which should be corrected by the Departments (DEPT) that occupy this building, Facilities Services (FS), Environmental Health & Safety (EHS), and Recycling (RECY). Please forward a copy of this report to the responsible group(s) and begin corrective action so that all deficiencies have been corrected prior to the reinspection date. If assistance is required from Facilities Services to estimate or correct an item assigned to a Department, contact the Work Coordination Center at ext. 7-2969.

### Facilities Services Priority Codes:

**Priority 1:** items are considered immediate safety hazards and should be corrected within 48 hours of notification if possible. If repairs cannot be made immediately, temporary measures may be taken.

**Priority 2:** items should be corrected within the five-week period before the scheduled reinspections.

**Priority 3:** items are long term fixes that should be either added to an ongoing work list or to the capital improvement list for campus upgrades.

### Comments:

Priority code	Standard in need of attention	Reg.Reference	Location	Resp	Observations & Recommendations	Date Corrected
1	Exit and exit access doors shall be marked by an approved exit sign readily visible from any direction of egress travel.	2019 OFC 1013.1	114:exit	Rossi, Cindy	Provide exit sign next to door on west side (men's locker room) and egress hardware on exit door (panic hardware).	
1	Door operating devices shall not require tight grasping, tight pinching or twisting of the wrist to operate.	2019 OFC 1010.1.9.1	Near 104:exit	<del>Grube, Arton</del> FS/ROSSI	On North door of ROTC, change door hardware to allow for exiting from interior. Discontinue using padlock on outside to prevent personnel from exiting.	

Priority code	Standard in need of attention	Reg.Reference	Location	Resp	Observations & Recommendations	<a href="#">Date Corrected</a>
1	Provide approved exit door hardware and/or maintain exit door.	2019 OFC 1010	MAC:exit	<del>Grube, Anton</del> FS	Adjust exit doors on east side of arena to function properly.	
1	Extension cords and flexible cords shall not be a substitute for permanent wiring.	2019 OFC 604.5	BASEBALL:inside	<del>UP/OS</del> ATHLETICS	Discontinue use of extension cords in place of permanent wiring in baseball area. Items that need to be plugged directly into an outlet are: TV, pitching machines (use floor outlet or longer cord from manufacturer), and Hit Trax machine.	