

Building Manager: [William Callender, bill.callender@oregonstate.edu](mailto:bill.callender@oregonstate.edu)
 Assessment Date: 12/14/2021
 Assessment Number: **10466**
 Location: McAlexander Field House Entire
 Reinspection date:

A joint fire safety inspection of the facility listed above was performed by the Environmental Health & Safety - Fire and Life Safety and the Corvallis Fire Department. These fire safety deficiencies could result in a fire or jeopardize the safety of those occupying the facility. Please see that these items are corrected immediately and no later than the scheduled reinspection date noted with this report. If you have any questions regarding this inspection, please email Brian Lilley (EH&S - Fire and Life Safety) at brian.lilley@oregonstate.edu.

Note: Deficiencies that are bold and underlined remain uncorrected from the last fire/life safety inspection(s) and should be corrected immediately.

* Annotates a deficiency identified by the Corvallis Fire Department.

Indicated on the report are items which should be corrected by the Departments (DEPT) that occupy this building, Facilities Services (FS), Environmental Health & Safety (EHS), and Recycling (RECY). Please forward a copy of this report to the responsible group(s) and begin corrective action so that all deficiencies have been corrected prior to the reinspection date. If assistance is required from Facilities Services to estimate or correct an item assigned to a Department, contact the Work Coordination Center at ext. 7-2969.

Facilities Services Priority Codes:

Priority 1: items are considered immediate safety hazards and should be corrected within 48 hours of notification if possible. If repairs cannot be made immediately, temporary measures may be taken.

Priority 2: items should be corrected within the five-week period before the scheduled reinspections.

Priority 3: items are long term fixes that should be either added to an ongoing work list or to the capital improvement list for campus upgrades.

Comments:

Priority code	Standard in need of attention	Reg.Reference	Location	Resp	Observations & Recommendations	Date Corrected
2	Emergency lighting shall be maintained.	2019 OFC 1031.10	Fieldhouse:Above main entrance	FS	EXIT sign above main entrance of Fieldhouse displays faulty battery sign. 	

Priority code	Standard in need of attention	Reg.Reference	Location	Resp	Observations & Recommendations	Date Corrected
---------------	-------------------------------	---------------	----------	------	--------------------------------	----------------

2	Extension cords and flexible cords shall not be a substitute for permanent wiring.	2019 OFC 604.5	BASEBALL:inside	DEPT	Discontinue plugging extension cord into TV. A relocatable power tap (RPT) okay for use instead.	
---	--	----------------	-----------------	------	--	--



2	Discontinue use of extension cord not plugged directly into an approved receptacle. Do not chain together.	2019 OFC 604.5.1	304:inside	DEPT	Discontinue plugging extension cord into power strip.	
---	--	------------------	------------	------	---	--

