

Fire and Life Safety Report

Building Manager: [Anton Grube, grubean@oregonstate.edu](mailto:grubean@oregonstate.edu)
 Assessment Date: 12/2/2020
 Assessment Number: **9923**
 Location: McNary Hall Entire
 Reinspection date: 1/13/2021

A joint fire safety inspection of the facility listed above was performed by the Environmental Health & Safety - Fire and Life Safety and the Corvallis Fire Department. These fire safety deficiencies could result in a fire or jeopardize the safety of those occupying the facility. Please see that these items are corrected immediately and no later than the scheduled reinspection date noted with this report. If you have any questions regarding this inspection, please email Brian Lilley (EH&S - Fire and Life Safety) at brian.lilley@oregonstate.edu.

Note: Deficiencies that are bold and underlined remain uncorrected from the last fire/life safety inspection(s) and should be corrected immediately.

* Annotates a deficiency identified by the Corvallis Fire Department.

Indicated on the report are items which should be corrected by the Departments (DEPT) that occupy this building, Facilities Services (FS), Environmental Health & Safety (EHS), and Recycling (RECY). Please forward a copy of this report to the responsible group(s) and begin corrective action so that all deficiencies have been corrected prior to the reinspection date. If assistance is required from Facilities Services to estimate or correct an item assigned to a Department, contact the Work Coordination Center at ext. 7-2969.

Facilities Services Priority Codes:

Priority 1: items are considered immediate safety hazards and should be corrected within 48 hours of notification if possible. If repairs cannot be made immediately, temporary measures may be taken.

Priority 2: items should be corrected within the five-week period before the scheduled reinspections.

Priority 3: items are long term fixes that should be either added to an ongoing work list or to the capital improvement list for campus upgrades.

Comments:

Priority code	Standard in need of attention	Reg.Reference	Location	Resp	Observations & Recommendations	Date Corrected
2	Approved covers shall be provided for all switch and electrical outlet boxes.	2019 OFC 604.6	004:inside	Anton Grube	Replace cover plate for junction box.	
2	Extension cords and flexible cords shall not be a substitute for permanent wiring.	2019 OFC 604.5	125:inside	UHDS	Plug decorative lights into outlet or appropriate relocatable power tap. Do not plug into extension cord.	

Priority code	<u>Standard in need of attention</u>	<u>Reg.Reference</u>	<u>Location</u>	<u>Resp</u>	<u>Observations & Recommendations</u>	<u>Date Corrected</u>
2	Power strips, extension cords, or any other electrical cord shall not extend through walls, ceilings, floors, under doors or floor coverings, or be subject to damage.	2019 OFC 604.5	532:inside	Grube, Anton	Remove LED light strip from under door.	
2	Additional Findings:		N003:inside	UHDS	Repair/replace basement ceiling tile.	