

Building Manager: [Shirley Renee Mann, shirley.mann@oregonstate.edu](mailto:shirley.mann@oregonstate.edu)
 Assessment Date: 1/5/2022
 Assessment Number: **10501**
 Location: Moreland Hall Entire
 Reinspection date:

A joint fire safety inspection of the facility listed above was performed by the Environmental Health & Safety - Fire and Life Safety and the Corvallis Fire Department. These fire safety deficiencies could result in a fire or jeopardize the safety of those occupying the facility. Please see that these items are corrected immediately and no later than the scheduled reinspection date noted with this report. If you have any questions regarding this inspection, please email Brian Lilley (EH&S - Fire and Life Safety) at brian.lilley@oregonstate.edu.

Note: Deficiencies that are bold and underlined remain uncorrected from the last fire/life safety inspection(s) and should be corrected immediately.

* Annotates a deficiency identified by the Corvallis Fire Department.

Indicated on the report are items which should be corrected by the Departments (DEPT) that occupy this building, Facilities Services (FS), Environmental Health & Safety (EHS), and Recycling (RECY). Please forward a copy of this report to the responsible group(s) and begin corrective action so that all deficiencies have been corrected prior to the reinspection date. If assistance is required from Facilities Services to estimate or correct an item assigned to a Department, contact the Work Coordination Center at ext. 7-2969.

Facilities Services Priority Codes:

Priority 1: items are considered immediate safety hazards and should be corrected within 48 hours of notification if possible. If repairs cannot be made immediately, temporary measures may be taken.

Priority 2: items should be corrected within the five-week period before the scheduled reinspections.

Priority 3: items are long term fixes that should be either added to an ongoing work list or to the capital improvement list for campus upgrades.

Comments:

| Priority code | Standard in need of attention | Reg.Reference | Location | Resp | Observations & Recommendations | Date Corrected |
|----------------------|--|----------------------|-----------------|-------------|---|---------------------------------------|
| 1 | Door operating devices shall not require tight grasping, tight pinching or twisting of the wrist to operate. | 2019 OFC 1010.1.9.1 | Throughout:exit | FS | ALL Doors in the egress pathway of the building need evaluation and IMMEDIATE change of hardware. | |

**Priority
code**

Standard in need of attention

Reg.Reference

Location

Resp

Observations & Recommendations

[Date Corrected](#)



ALL doors in egress pathway or at exits

| | | | | | |
|---|--|------------------|---------------------|------|---|
| 2 | Provide inspection, testing, and maintenance documentation for fire escape(s). | 2019 OFC 1031.11 | Throughout:exterior | FS | Provide documentation of 5 year testing. |
| 2 | Materials susceptible to spontaneous ignition, such as oily rags, shall be stored in a listed disposal container. Contents shall be disposed of daily. | 2019 OFC 304.3.1 | 130A:inside | DEPT | Remove contents of container DAILY when in use. |



Room 130A