

NOTICE OF FIRE SAFETY INSPECTION OREGON STATE UNIVERSITY



Facility Inspected: Precision Agricultural Systems Center
 Inspection Date: 06/04/18 3:42 PM
 Reinspect Date: 07/25/18 8:00 AM

A fire safety inspection of the facility listed above was performed by the Corvallis Fire Prevention Bureau. These fire safety deficiencies could result in a fire or jeopardize the safety of those occupying the facility. Please see that these items are corrected immediately. If you have any questions regarding this inspection, please phone me at 737-3066. Thank you for your cooperation and support for fire safety. Jim Patton, Fire Prevention Officer, jim.patton@oregonstate.edu

Note: Deficiencies that are bold and underlined remain uncorrected from the last fire/life safety inspection(s) and should be corrected immediately.

** Annotates a deficiency identified by OSU Environmental health and safety Department. Direct any questions regarding these items to that office (737-2273).*

Indicated on the report are items which should be correct by the Departments (DEPT) that occupy this building, Facilities Services (FS), Environmental Health and Safety (EHS), and Recycling (RECY). Please forward a copy of this report to the responsible group(s) and begin corrective action to be completed no later than the reinspection date.

Facilities Services Priority Codes:

Priority 1: (p1) items are considered immediate safety hazards and should be corrected within 48 hours of notification if possible. If repairs cannot be made immediately, temporary measures may be taken.

Priority 2: (p2) items should be corrected within the five-week period before the scheduled reinspections.

Priority 3: (p3) items are long term fixes that should be either added to an ongoing work list (such as annual testing of building sprinkler systems) or to the capital improvement list for campus upgrades.

The due date is listed at the top of this page. If you have any questions, require additional information, or feel the items have been improperly assigned, feel free to contact Jim Patton (Corvallis Fire Department) at 737-3066. If assistance is required from Facilities Services to estimate or correct an item assigned to a Department, contact the Work Coordination Center at ext. 7-2969. MS Excel format is available upon request.

Completed	Priority	Responsible Party	Location	Description	Code Reference	Notes
	2	Key Shop	Data Center	Knox box and keys shall be provided for buildings with fire alarms or sprinkler systems.	CFC 506.1	NEW - Provide a key/fob to Data Center portion of the building
X	2	Key Shop	TO DATA CENTER WING	Knox box and keys shall be provided for buildings with fire alarms or sprinkler systems.	CFC 506.1	
X	2	EH&S	Throughout	Extinguishers shall be tagged and inspected annually. Recharge every 6 years. Hydrotest every 12 years.	"CFC 906.2, NFPA 10"	
	2	Facilities Services		Inspect and test fire alarm system in accordance with nationally recognized standards. Affix inspection tag to system.	"CFC 907.8, NFPA 72"	

2	Facilities Services	Sprinklers - Inspect and tag annually; flow test and tag every 5 years.	"CFC 906.6.1, NFPA 25"
---	------------------------	--	------------------------------