

NOTICE OF FIRE SAFETY INSPECTION OREGON STATE UNIVERSITY

Facility Inspected: Property Services
 Inspection Date: 08/06/19 2:01 PM
 Reinspect Date:

A fire safety inspection of the facility listed above was performed by the EH&S Fire and Life Safety Department. These fire safety deficiencies could result in a fire or jeopardize the safety of those occupying the facility. Please see that these items are corrected immediately. If you have any questions regarding this inspection, please email me. Thank you for your cooperation and support for fire safety. Jim Patton, Fire Safety Officer, jim.patton@oregonstate.edu

Note: Deficiencies that are bold and underlined remain uncorrected from the last fire/life safety inspection(s) and should be corrected immediately.

* Annotates a deficiency identified by OSU Environmental health and safety Department. Direct any questions regarding these items to that office (737-2273).

Indicated on the report are items which should be correct by the Departments (DEPT) that occupy this building, Facilities Services (FS), Environmental Health and Safety (EHS), and Recycling (RECY). Please forward a copy of this report to the responsible group(s) and begin corrective action to be completed no later than the reinspection date.

Facilities Services Priority Codes:

Priority 1: (p1) items are considered immediate safety hazards and should be corrected within 48 hours of notification if possible. If repairs cannot be made immediately, temporary measures may be taken.

Priority 2: (p2) items should be corrected within the five-week period before the scheduled reinspections.

Priority 3: (p3) items are long term fixes that should be either added to an ongoing work list (such as annual testing of building sprinkler systems) or to the capital improvement list for campus upgrades.

The due date is listed at the top of this page. If you have any questions, require additional information, or feel the items have been improperly assigned, feel free to contact Jim Patton (Fire and Life Safety) at jim.patton@oregonstate.edu. If assistance is required from Facilities Services to estimate or correct an item assigned to a Department, contact the Work Coordination Center at ext. 7-2969. MS Excel format is available upon request.

Completed	Priority	Responsible Party	Location	Description	Code Reference	Notes
	2	Department	Peterson Cubicle	Discard old portable space heater without UL listing.		
	2	Department	Room 106	Plug space heaters directly into wall receptacle not into power strip or extension cord.		
	2	Department	eBay Area	Discontinue the use of non fuse protected extension cords in place of permanent wiring. Fuse protected power strips are acceptable.	"CFC 605.4, 605.5"	Orange cord; and reconfigure devices into power strip (under desk) as one does not plug in all the way and plug blades are exposed.
	1	Department	Near Copier in Service desk Area	"Cords shall not be affixed to, or extend through, walls, ceilings, floors, under doors, and shall not be subject to physical damage."	CFC 605.4.3	Power strip cord being pinched by counter unit. Correct and replace power strip.
	2	Department	Receiving Area	Plug power strips directly into outlet. Do not chain one to another.	CFC 605.4.2	
	3	Department	Main Warehouse Area	Reduce combustible storage above 12'. Work toward replacing combustible storage above 12' with non-combustible material, otherwise minimize amount of combustible material above 12'		
	2	Department	Near Electronics area	If grinder produces sparks provide an approved non-combustible shroud or relocate in an area completely free of combustible material (such as outside).		
	2	Department	Electronics Area	Discontinue the use of non fuse protected extension cords in place of permanent wiring. Fuse protected power strips are acceptable.	"CFC 605.4, 605.5"	Remove all extension cords and replace with power strips and clean up all other cord issues.