



## NOTICE OF FIRE SAFETY INSPECTION OREGON STATE UNIVERSITY

Facility Inspected: Radiation Center  
 Inspection Date: 08/27/20 2:54 PM  
 Reinspect Date:

A joint fire safety inspection of the facility listed above was performed by the Environmental Health & Safety - Fire and Life Safety and the Corvallis Fire Department. These fire safety deficiencies could result in a fire or jeopardize the safety of those occupying the facility. Please see that these items are corrected immediately and no later than the scheduled reinspection date listed in the accompanying email. If you have any questions regarding this inspection, please email me. Thank you for your cooperation and support for fire safety. Jim Patton, Fire Safety Officer, jim.patton@oregonstate.edu

**Note: Deficiencies that are bold and underlined remain uncorrected from the last fire/life safety inspection(s) and should be corrected immediately.**

\* Annotates a deficiency identified by the Corvallis Fire Department..

Indicated on the report are items which should be correct by the Departments (DEPT) that occupy this building, Facilities Services (FS), Environmental Health and Safety (EHS), and Recycling (RECY). Please forward a copy of this report to the responsible group(s) and begin corrective action so that all deficiencies have been corrected prior to the reinspection date.

### Facilities Services Priority Codes:

**Priority 1:** items are considered immediate safety hazards and should be corrected within 48 hours of notification if possible. If repairs cannot be made immediately, temporary measures may be taken.

**Priority 2:** items should be corrected within the five-week period before the scheduled reinspections.

**Priority 3:** items are long term fixes that should be either added to an ongoing work list or to the capital improvement list for campus upgrades.

The due date is listed in the body of the Email. If you have any questions, require additional information, or feel the items have been improperly assigned, feel free to contact Brian Lilley (EH&S - Fire and Life Safety) at brian.lilley@oregonstate.edu. If assistance is required from Facilities Services to estimate or correct an item assigned to a Department, contact the Work Coordination Center at ext. 7-2969.

Completed	Priority	Responsible Party	Location	Description	Code Reference	Notes
	1	Facilities Services		Fire alarm and fire detection systems shall be tested in accordance with this standard. Affix inspection tag to system.	2019 OFC 907.8	Provide documentation fire alarm panel has been maintained. Tag missing/non-existent.
	1	Department	Throughout	Discontinue plugging high power or heat producing appliances into power strips or extension cords. Always plug appliances into wall receptacles. - OSFM Rule & 2019 OFC 604.5.2		
	1	Department	B116	"Individual containers, cartons or packages shall be marked or labeled in an approved manner."	2019 OFC 5003.5.1	Relocate contents of apple juice container into an approved receptacle and label appropriately.
	1	Department	A136	Label chemical cabinet with correct hazardous material storage.		
	1	Department	A136	"Power strips, extension cords or any other electrical cord shall not extend through walls, ceilings, floors, under doors or floor coverings, or be subject to damage."	2019 OFC 604.5	Mount power strip to ensure no strain is occurring on plug connection.
	1	Department	A144	"In all occupancies, quantities of flammable and combustible liquids in excess of 10 gallons shall be stored in a flammable cabinet."	2019 OFC 5704.3.4.4	
	2	EH&S	C106	Explore the potential oxygen displacement concern in this lab to determine if a hazardous condition potentially exists and institute corrective action as needed. - 2019 OFC 5307		
	1	Department	C126	Combustible material shall not be allowed to accumulate in buildings or structures.	2019 OFC 304.1	

---

1	Department	A144, C128, E118, 400A	Discontinue use of extension cord not plugged directly into an approved receptacle. Do not chain together.	2019 OFC 604.5.1
---	------------	---------------------------------	--	---------------------