



**NOTICE OF FIRE SAFETY INSPECTION OREGON STATE UNIVERSITY**

Facility Inspected: VF Vegetable Lab Building  
 Inspection Date: 07/28/20 7:41 AM  
 Reinspect Date:

A joint fire safety inspection of the facility listed above was performed by the Environmental Health & Safety - Fire and Life Safety Department and the Corvallis Fire Department. These fire safety deficiencies could result in a fire or jeopardize the safety of those occupying the facility. Please see that these items are corrected immediately and no later than the scheduled reinspection date listed in the accompanying email. If you have any questions regarding this inspection, please email me. Thank you for your cooperation and support for fire safety. Jim Patton, Fire Safety Officer, jim.patton@oregonstate.edu

**Note: Deficiencies that are bold and underlined remain uncorrected from the last fire/life safety inspection(s) and should be corrected immediately.**

*\* Annotates a deficiency identified by the Corvallis Fire Department..*

*Indicated on the report are items which should be correct by the Departments (DEPT) that occupy this building, Facilities Services (FS), Environmental Health and Safety (EHS), and Recycling (RECY). Please forward a copy of this report to the responsible group(s) and begin corrective action so that all deficiencies have been corrected prior to the reinspection date.*

**Facilities Services Priority Codes:**

**Priority 1:** items are considered immediate safety hazards and should be corrected within 48 hours of notification if possible. If repairs cannot be made immediately, temporary measures may be taken.

**Priority 2:** items should be corrected within the five-week period before the scheduled reinspections.

**Priority 3:** items are long term fixes that should be either added to an ongoing work list or to the capital improvement list for campus upgrades.

*The due date is listed in the body of the Email. If you have any questions, require additional information, or feel the items have been improperly assigned, feel free to contact Brian Lilley (EH&S - Fire and Life Safety) at brian.lilley@oregonstate.edu. If assistance is required from Facilities Services to estimate or correct an item assigned to a Department, contact the Work Coordination Center at ext. 7-2969.*

Completed	Priority	Responsible Party	Location	Description	Code Reference	Notes
	1	Department	Vegetable Lab	Discontinue plugging high power or heat producing appliances into power strips or extension cords. Always plug appliances into wall receptacles. - OSFM Rule & 2019 OFC 604.5.2		Microwave and toaster oven.
	1	Department	Hazelnut Lab	"Curtains, draperies, fabric hangings and other similar combustible decorative materials suspended from walls or ceilings shall be flame retardant, tested, and not exceed 10 percent of a specific wall or ceiling area."	2019 OFC 807.2 & 807.3	Plastic barrier must be treated with a flame retardant spray or removed from room.
	1	Department	Shop A	Extension cords and flexible cords shall not be a substitute for permanent wiring.	2019 OFC 604.5	Discontinue using extension cord for ceiling shop lights. Plug lights into ceiling/wall receptacle.
	1	Department	Shop A	Compressed gas cylinders shall be secured with one or more restraint to prevent falling.	2019 OFC 5303.5.3	
	1	Department	Shop A	Maintain housekeeping of metal shavings. - NFPA 484		
	1	Department	Chemical Shed	"Individual containers, cartons or packages shall be marked or labeled in an approved manner."	2019 OFC 5003.5.1	Label white plastic barrel near roll-up doors with container contents.