

# NOTICE OF FIRE SAFETY INSPECTION OREGON STATE UNIVERSITY

Facility Inspected: Vet Dairy Barn  
 Inspection Date: 06/10/19 3:00 PM  
 Reinspect Date: 07/11/19 8:00 AM

A fire safety inspection of the facility listed above was performed by the Corvallis Fire Prevention Bureau. These fire safety deficiencies could result in a fire or jeopardize the safety of those occupying the facility. Please see that these items are corrected immediately. If you have any questions regarding this inspection, please phone me at 737-3066. Thank you for your cooperation and support for fire safety. Jim Patton, Fire Prevention Officer, jim.patton@oregonstate.edu

**Note: Deficiencies that are bold and underlined remain uncorrected from the last fire/life safety inspection(s) and should be corrected immediately.**

\* Annotates a deficiency identified by OSU Environmental health and safety Department. Direct any questions regarding these items to that office (737-2273).

Indicated on the report are items which should be correct by the Departments (DEPT) that occupy this building, Facilities Services (FS), Environmental Health and Safety (EHS), and Recycling (RECY). Please forward a copy of this report to the responsible group(s) and begin corrective action to be completed no later than the reinspection date.

**Facilities Services Priority Codes:**

**Priority 1:** (p1) items are considered immediate safety hazards and should be corrected within 48 hours of notification if possible. If repairs cannot be made immediately, temporary measures may be taken.

**Priority 2:** (p2) items should be corrected within the five-week period before the scheduled reinspections.

**Priority 3:** (p3) items are long term fixes that should be either added to an ongoing work list (such as annual testing of building sprinkler systems) or to the capital improvement list for campus upgrades.

The due date is listed at the top of this page. If you have any questions, require additional information, or feel the items have been improperly assigned, feel free to contact Jim Patton (Corvallis Fire Department) at 737-3066. If assistance is required from Facilities Services to estimate or correct an item assigned to a Department, contact the Work Coordination Center at ext. 7-2969. MS Excel format is available upon request.

Completed	Priority	Responsible Party	Location	Description	Code Reference	Notes
X	2	Facilities Services	South Side Exterior	Address identification must be visible from the street (new installations - minimum number height = 6 inches).	CFC 505.1	Provide highly visible address numbers or approved monument sign facing Washington Way so as to be readily seen from the street.
X	2	Department	Near Office	Abate Electrical Hazard	CFC 605.1	Remove power strip from desk drawer. Also Don't suspend power strips.
X	2	EH&S	Upstairs near stairs.	"Provide a 2A:10BC fire extinguisher for every 3,000 square feet, with a maximum travel distance of 75 feet. Additional requirements for hazardous areas."	"CFC 906.1, NFPA 10"	
X	1	Department	Upstairs	Replace bar over opening in floor whenever material is not being actively moved. EH&S/OSHA requirement		
X	2	Department	Room 005	Discontinue the use of non fuse protected extension cords in place of permanent wiring. Fuse protected power strips are acceptable.	"CFC 605.4, 605.5"	Plug large refrigerators directly into wall receptacle as opposed to extension cords or power strips.
X	2	Department	NE Corner Main Floor	What is the black drum of flammable liquid used for? Can it be removed and turned in to EH&S? If needed provide an approved storage location or cabinet.		
X	2	Department	Throughout	Discontinue the use of non fuse protected extension cords in place of permanent wiring. Fuse protected power strips are acceptable.	"CFC 605.4, 605.5"	Unplug extension cords and other appliances when not in use.
	2	Department	Main Bay	Clean up sawdust on floor after every use or provide an approved dust collection device or system.		
X		Department	Throughout	NOTE: Ensure NO "Hot Work" occurs in this building without an approved permit from EH&S		
	2	Department	Room 12	Secure drill press to floor. (EH&S requirement)		