

OSU Drinking Water Sampling Results - 1988:2005

9/7/2016

During sampling, if the EPA action level was exceeded for lead, mandatory repairs were typically made to the water supply system (replacing piping and/or fixtures). NT = not tested. ND = not detected

Action level or maximum contaminant level

15 1.3 0.3

| Date | Time | Building | Room/ Location | Source | Lead (ug/L) | Copper (mg/L) | Iron (mg/L) | year |
|------------|---------|------------------|----------------|--------|-------------|---------------|-------------|------|
| 10/27/1994 | 1520 | Adams Hall | 101 | si | 1.0 | 0.020 | 0.010 | 1994 |
| 9/18/1996 | 7:20 AM | Adams Hall | 101 | sink | 1 | 0.05 | 0.58 | 1996 |
| 9/18/1996 | 7:21 AM | Adams Hall | 110 | df | 1 | 0.80 | 0.03 | 1996 |
| 8/28/1994 | 0939 | Aero Engineering | 101 | si | 1.0 | 0.020 | 0.280 | 1994 |
| 1995 | -- | Aero Engineering | 101 | SI | 0 | 0.02 | 0.39 | 1905 |
| 12/22/1999 | -- | Aero Engineering | 101 | Sink | 1 | 0.01 | 0.1 | 1999 |
| 10/5/1994 | 0708 | Ag & Life Sci | 0018 | df | 1.0 | 0.530 | 0.070 | 1994 |
| 10/27/97 | 6:58 AM | Ag & Life Sci | 0018 | DF | 1 | 1.75 | 0.01 | 1997 |
| 2001-2002 | -- | Ag & Life Sci | 0018 | df | 1 | 1.31 | 0.02 | 2001 |
| 10/27/97 | 6:56 AM | Ag & Life Sci | 1019 | DF | 1 | 1.38 | 0.01 | 1997 |
| 2001-2002 | -- | Ag & Life Sci | 1019 | df | 0 | 0.43 | 0.02 | 2001 |
| 10/27/97 | 6:54 AM | Ag & Life Sci | 2009 | sink | 1 | 2.32 | 0.02 | 1997 |
| 1995 | -- | Ag & Life Sci | 2009 | SI | 0 | 2.43 | 0.01 | 1905 |
| 2001-2002 | -- | Ag & Life Sci | 2009 | si | 0 | 0.96 | 0.03 | 2001 |
| 10/5/1994 | 0717 | Ag & Life Sci | 2017 | df | 0.1 | 1.020 | 0.010 | 1994 |
| 10/27/97 | 6:53 AM | Ag & Life Sci | 2017 | DF | 16 | 1.27 | 0.01 | 1997 |
| 2001-2002 | -- | Ag & Life Sci | 2017 | df | 0 | 0.49 | 0.01 | 2001 |
| 10/27/97 | 6:51 AM | Ag & Life Sci | 3021 | DF | 1 | 1.56 | 0.01 | 1997 |
| 2001-2002 | -- | Ag & Life Sci | 3021 | df | 0 | 0.6 | 0.03 | 2001 |
| 10/27/97 | 6:43 AM | Ag & Life Sci | 4007 | sink | 9 | 1.78 | 0.01 | 1997 |
| 10/27/97 | 6:45 AM | Ag & Life Sci | 4018 | DF | 1 | 0.68 | 0.01 | 1997 |
| 2001-2002 | -- | Ag & Life Sci | 4018 | si | 0 | 0.19 | 0 | 2001 |
| 10/5/1994 | 0713 | Ag & Life Sci | 4021 | df | 0.1 | 1.130 | 0.010 | 1994 |
| 10/27/97 | 6:48 AM | Ag & Life Sci | 4021 | DF | 0 | 1.59 | 0.01 | 1997 |
| 2001-2002 | -- | Ag & Life Sci | 4021 | df | 0 | 0.78 | 0.01 | 2001 |
| 11/18/1994 | 1040 | Ag & Life Sci | 4103 | si | 7.0 | 1.330 | 0.010 | 1994 |
| 10/27/97 | 6:50 AM | Ag & Life Sci | 4103 | sink | 8 | 1.76 | 0.01 | 1997 |
| 11/18/1994 | 1055 | Ag & Life Sci | 4105 | si | 1.0 | 2.610 | 0.010 | 1994 |
| 10/5/1994 | 0738 | Apiary | 102 | si | 12.0 | 0.030 | 0.730 | 1994 |
| 1995 | -- | Apiary | 102 | SI | 1 | 0.02 | 0.37 | 1905 |
| 1995 | -- | Apiary | 104 | SI | 0 | 0.18 | 0.21 | 1905 |
| 8/30/1994 | 0645 | Apperson | 109 | df | 1.0 | 0.830 | 0.230 | 1994 |
| 12/13/1994 | 0715 | Apperson | 109 | df | 0.1 | NT | NT | 1994 |
| 12/13/1994 | 0721 | Apperson | 212 | df | 1.0 | NT | NT | 1994 |
| 11/03/97 | 7:37 AM | Apperson | 212 | DF | 0 | 0.63 | 0.38 | 1997 |
| 2001-2002 | -- | Apperson | 212 | df | 4 | 0.72 | 0.8 | 2001 |
| 12/13/1994 | 0720 | Apperson | 216 | si | 10.0 | NT | NT | 1994 |
| 8/30/1994 | 0548 | Apperson | 300 | df | 13.0 | 0.250 | 0.240 | 1994 |
| 12/13/1994 | 0722 | Apperson | 300 | df | 7.0 | NT | NT | 1994 |
| 11/03/97 | 7:33 AM | Apperson | 300 | DF | 1 | 0.51 | 0.23 | 1997 |
| 2001-2002 | -- | Apperson | 300 | df | 9 | 0.22 | 0.54 | 2001 |
| 11/03/97 | 6:55 AM | Ballard | 104 | sink | 0 | 0.70 | 0.01 | 1997 |
| 2001-2002 | -- | Ballard | 104 | df | 0 | 0.15 | 0.02 | 2001 |
| 8/28/1994 | 0848 | Ballard | 113 | df | 0.1 | 0.440 | 0.010 | 1994 |
| 11/03/97 | 6:52 AM | Ballard | 113 | DF | 1 | 0.39 | 0.01 | 1997 |
| 2001-2002 | -- | Ballard | 113 | df | 0 | 0.16 | 0.02 | 2001 |
| 8/28/1994 | 0851 | Ballard | 221 | df | 1.0 | 0.460 | 0.270 | 1994 |
| 11/03/97 | 7:04 AM | Ballard | 221 | DF | 1 | 0.71 | 0.09 | 1997 |
| 2001-2002 | -- | Ballard | 221 | df | 0 | 0.19 | 0.02 | 2001 |
| 11/03/97 | 7:08 AM | Ballard | 234 | sink | 2 | 0.76 | 0.01 | 1997 |
| 2001-2002 | -- | Ballard | 234 | si | 0 | 0.1 | 0.02 | 2001 |
| 11/7/1988 | 8:10 AM | Ballard | 303 | sink | 21 | 0.014 | 1.72 | 1988 |
| 11/03/97 | 7:05 AM | Ballard | 303 | sink | 4 | 1.22 | 0.01 | 1997 |
| 11/03/97 | 7:00 AM | Ballard | 321 | DF | 1 | 1.23 | 0.01 | 1997 |
| 2001-2002 | -- | Ballard | 321 | si | 0 | 0.55 | 0.01 | 2001 |
| 8/25/1994 | 0810 | Batcheller | 152 | df | 1.0 | 0.030 | 0.440 | 1994 |

OSU Drinking Water Sampling Results - 1988:2005

9/7/2016

During sampling, if the EPA action level was exceeded for lead, mandatory repairs were typically made to the water supply system (replacing piping and/or fixtures). NT = not tested. ND = not detected

Action level or maximum contaminant level

15 1.3 0.3

| Date | Time | Building | Room/ Location | Source | Lead (ug/L) | Copper (mg/L) | Iron (mg/L) | year |
|------------|---------|------------------|----------------|--------|-------------|---------------|-------------|------|
| 09/22/97 | 7:32 AM | Batcheller | 152 | DF | 0 | 0.02 | 0.69 | 1997 |
| 2001-2002 | -- | Batcheller | 152 | df | 0 | 0.08 | 0.4 | 2001 |
| 8/25/1994 | 0805 | Batcheller | 341 | si | 5.0 | 1.050 | 0.900 | 1994 |
| 09/22/97 | 7:35 AM | Batcheller | 341 | sink | 1 | 0.92 | 0.62 | 1997 |
| 2001-2002 | -- | Batcheller | 341 | si | 0 | 0.73 | 0.49 | 2001 |
| 11/03/97 | 6:39 AM | Bates | 115 | sink | 1 | 0.88 | 0.40 | 1997 |
| 11/03/97 | 6:40 AM | Bates | 117 | DF | 0 | 0.56 | 0.15 | 1997 |
| 8/28/1994 | 0857 | Bates | 121 | si | 3.0 | 0.840 | 0.470 | 1994 |
| 11/03/97 | 6:37 AM | Bates | 121 | sink | 12 | 0.47 | 0.13 | 1997 |
| 8/28/1994 | 0900 | Bates | 207 | df | 1.0 | 0.670 | 0.230 | 1994 |
| 11/03/97 | 6:42 AM | Bates | 214 | DF | 0 | 0.60 | 0.17 | 1997 |
| 2001-2002 | -- | Bates | 214 | df | 0 | 0.24 | 0.34 | 2001 |
| 12/12/1994 | 1610 | Benton Annex | 0002 | si | 13.0 | NT | NT | 1994 |
| 9/17/1996 | 8:15 AM | Benton Annex | 003 | sink | 1 | 0.01 | 0.04 | 1996 |
| 9/17/1996 | 8:10 AM | Benton Annex | 020 | sink | 2 | 0.01 | 0.09 | 1996 |
| 12/12/1994 | 1600 | Benton Annex | 020A | si | 1.0 | NT | NT | 1994 |
| 8/30/1994 | 0706 | Benton Annex | 020C | si | 13.0 | 0.010 | 0.260 | 1994 |
| 12/12/1994 | 1600 | Benton Annex | 020C | si | 1.0 | NT | NT | 1994 |
| 9/18/1996 | 7:45 AM | Benton Hall | 105A | sink | 1 | 0.28 | 0.37 | 1996 |
| 8/30/1994 | 0700 | Benton Hall | 107 | df | 2.0 | 0.040 | 0.960 | 1994 |
| 9/17/1996 | 8:19 AM | Benton Hall | 107 | df | 1 | 0.05 | 1.13 | 1996 |
| 8/30/1994 | 0703 | Benton Hall | 305 | df | 9.0 | 0.290 | 0.290 | 1994 |
| 9/17/1996 | 8:20 AM | Benton Hall | 305 | df | 8 | 0.27 | 0.56 | 1996 |
| 09/22/97 | 7:41 AM | Bexell | 103 | DF | 1 | 1.12 | 0.01 | 1997 |
| 2001-2002 | -- | Bexell | 103 | df | 0 | 0.31 | 0.02 | 2001 |
| 8/23/1994 | 0829 | Bexell | 106 | df | 0.1 | 0.950 | 0.180 | 1994 |
| 09/22/97 | 7:40 AM | Bexell | 110 | sink | 5 | 1.58 | 0.01 | 1997 |
| 2001-2002 | -- | Bexell | 110 | si | 0 | 0.47 | 0.02 | 2001 |
| 09/22/97 | 7:43 AM | Bexell | 207 | DF | 1 | 0.89 | 0.01 | 1997 |
| 2001-2002 | -- | Bexell | 207 | df | 0 | 0.23 | 0.01 | 2001 |
| 09/22/97 | 7:45 AM | Bexell | 324 | DF | 1 | 1.45 | 0.01 | 1997 |
| 2001-2002 | -- | Bexell | 324 | df | 0 | 0.63 | 0.02 | 2001 |
| 8/23/1994 | 0835 | Bexell | 414 | df | 0.1 | 1.380 | 0.110 | 1994 |
| 09/22/97 | 7:50 AM | Bexell | 416 | DF | 1 | 1.58 | 0.01 | 1997 |
| 2001-2002 | -- | Bexell | 416 | df | 0 | 0.88 | 0.01 | 2001 |
| 9/28/1994 | 0700 | Burt | 114 | df | 1.0 | 0.230 | 0.001 | 1994 |
| 9/28/1994 | 0702 | Burt | 318 | df | 0.1 | 1.150 | 0.030 | 1994 |
| 9/28/1994 | 0707 | Burt | 376 | df | 1.0 | 2.230 | 0.010 | 1994 |
| 10/27/1994 | 1520 | Cascade | 100 | df | 2.0 | 0.060 | 0.120 | 1994 |
| 10/4/1996 | 7:19 AM | Cascade 1st fl | back | df | 0 | 1.31 | 0.00 | 1996 |
| 10/4/1996 | 7:20 AM | Cascade 1st fl | back | sink | 1 | 1.51 | 0.00 | 1996 |
| 10/4/1996 | 7:23 AM | Cascade 1st fl | break | sink | 13 | 0.76 | 0.00 | 1996 |
| 10/4/1996 | 7:25 AM | Cascade 1st fl | entry | df | 4 | 0.80 | 0.00 | 1996 |
| 10/4/1996 | 7:30 AM | Cascade 2nd fl | break | sink | 12 | 0.53 | 0.00 | 1996 |
| 10/4/1996 | 7:27 AM | Cascade 2nd fl | landing | df | 1 | 0.74 | 0.00 | 1996 |
| 1995 | -- | Clark Meat Lab | 102 | SI | 3 | 0.01 | 0.34 | 1905 |
| 1995 | -- | Clark Meat Lab | 106 | DF | 2 | 0.01 | 0.15 | 1905 |
| 9/28/1994 | 0805 | Clark Meat Lab | 106 | df | 21.0 | 0.070 | 1.450 | 1994 |
| 8/30/1994 | 0902 | computer science | 007 | df | 1.0 | 0.150 | 0.150 | 1994 |
| 8/30/1994 | 0904 | computer science | 105A | si | 0.1 | 0.010 | 0.220 | 1994 |
| 1995 | -- | Cordley | 1000 | DF | 0 | 1.65 | 0.02 | 1905 |
| 1/21/2000 | -- | Cordley | 1000 | DF | 0 | 0.1 | 0.01 | 2000 |
| 1995 | -- | Cordley | 1010 | DF | 0 | 2.46 | 0.11 | 1905 |
| 1/21/2000 | -- | Cordley | 1010 | DF | 0 | 1.35 | 0.06 | 2000 |
| 1995 | -- | Cordley | 1047 | DF | 0 | 1.24 | 0.01 | 1905 |
| 1/21/2000 | -- | Cordley | 1047 | DF | 0 | 0.48 | 0.01 | 2000 |

OSU Drinking Water Sampling Results - 1988:2005

9/7/2016

During sampling, if the EPA action level was exceeded for lead, mandatory repairs were typically made to the water supply system (replacing piping and/or fixtures). NT = not tested. ND = not detected

| Action level or maximum contaminant level | | | | | 15 | 1.3 | 0.3 | |
|---|---------|--------------|----------------|--------|-------------|---------------|-------------|------|
| Date | Time | Building | Room/ Location | Source | Lead (ug/L) | Copper (mg/L) | Iron (mg/L) | year |
| 1995 | -- | Cordley | 1074 | DF | 0 | 0.49 | 0.01 | 1905 |
| 1/21/2000 | -- | Cordley | 1074 | DF | 0 | 0.57 | 0.01 | 2000 |
| 1995 | -- | Cordley | 1106 | DF | 0 | 1.92 | 0.01 | 1905 |
| 1/21/2000 | -- | Cordley | 1106 | DF | 0 | 0.71 | 0.02 | 2000 |
| 1995 | -- | Cordley | 2012 | DF | 0 | 1.22 | 0.02 | 1905 |
| 1/21/2000 | -- | Cordley | 2012 | DF | 0 | 0.19 | 0.01 | 2000 |
| 1995 | -- | Cordley | 2041 | DF | 1 | 2.07 | 0.01 | 1905 |
| 1/21/2000 | -- | Cordley | 2041 | DF | 0 | 1.14 | 0.03 | 2000 |
| 1995 | -- | Cordley | 2062 | DF | 3 | 1.43 | 0.01 | 1905 |
| 1/21/2000 | -- | Cordley | 2062 | DF | 1 | 0.79 | 0.03 | 2000 |
| 1995 | -- | Cordley | 2101 | DF | 1 | 1.21 | 0.02 | 1905 |
| 1/21/2000 | -- | Cordley | 2101 | DF | 0 | 0.07 | 0.01 | 2000 |
| 1995 | -- | Cordley | 3012 | DF | 1 | 1.22 | 0.02 | 1905 |
| 1/21/2000 | -- | Cordley | 3012 | DF | 0 | 0.19 | 0.02 | 2000 |
| 1995 | -- | Cordley | 3049 | DF | 0 | 2.02 | 0.08 | 1905 |
| 1/21/2000 | -- | Cordley | 3049 | DF | 0 | 1.33 | 0.02 | 2000 |
| 1995 | -- | Cordley | 3072 | DF | 0 | 1.08 | 0.01 | 1905 |
| 1/21/2000 | -- | Cordley | 3072 | DF | 0 | 0.2 | 0.01 | 2000 |
| 1995 | -- | Cordley | 3119 | DF | 0 | 0.98 | 0.02 | 1905 |
| 1/21/2000 | -- | Cordley | 3119 | DF | 0 | 0.07 | 0.01 | 2000 |
| 1995 | -- | Cordley | 4016 | DF | 1 | 1.43 | 0.03 | 1905 |
| 1/21/2000 | -- | Cordley | 4016 | DF | 0 | 0.24 | 0.01 | 2000 |
| 1995 | -- | Cordley | 4047 | DF | 1 | 1.31 | 0.01 | 1905 |
| 1/21/2000 | -- | Cordley | 4047 | DF | 0 | 0.36 | 0.02 | 2000 |
| 1995 | -- | Cordley | 4072 | DF | 0 | 2.24 | 0.01 | 1905 |
| 1/21/2000 | -- | Cordley | 4072 | DF | 0 | 1.01 | 0.01 | 2000 |
| 1995 | -- | Cordley | 4113 | DF | 0 | 1.53 | 0.01 | 1905 |
| 1/21/2000 | -- | Cordley | 4113 | DF | 0 | 0.21 | 0.02 | 2000 |
| 1995 | -- | Cordley | 5012 | DF | 0 | 0.72 | 0.02 | 1905 |
| 1/21/2000 | -- | Cordley | 5012 | DF | 0 | 0.3 | 0.01 | 2000 |
| 1995 | -- | Cordley | 5089 | DF | 1 | 1.72 | 0.02 | 1905 |
| 1/21/2000 | -- | Cordley | 5089 | DF | 0 | 0.22 | 0.01 | 2000 |
| 8/25/1994 | 0818 | Covell Hall | 009 | df | 5.0 | 0.410 | 3.300 | 1994 |
| 09/22/97 | 7:26 AM | Covell Hall | 009 | DF | 7 | 0.85 | >3.3 | 1997 |
| 2001-2002 | -- | Covell Hall | 009 | df | 0 | 0.28 | 0.75 | 2001 |
| 09/22/97 | 7:30 AM | Covell Hall | 109 | DF | 1 | 0.28 | 1.09 | 1997 |
| 2001-2002 | -- | Covell Hall | 109 | df | 0 | 0.25 | 0.35 | 2001 |
| 8/25/1994 | 0814 | Covell Hall | 211 | df | 4.0 | 0.020 | 1.580 | 1994 |
| 09/22/97 | 7:28 AM | Covell Hall | 211 | DF | 1 | 0.05 | 0.63 | 1997 |
| 2001-2002 | -- | Covell Hall | 211 | df | 0 | 0.18 | 0.06 | 2001 |
| 8/28/1994 | 1100 | Crop Science | 008 | df | 1.0 | 0.320 | 0.190 | 1994 |
| 09/15/97 | 7:22 AM | Crop Science | 008 | DF | 0 | 0.34 | 0.53 | 1997 |
| 2001-2002 | -- | Crop Science | 008 | df | 6 | 0.1 | 0.14 | 2001 |
| 09/15/97 | 7:19 AM | Crop Science | 030 | sink | 0 | 0.62 | 0.27 | 1997 |
| 2001-2002 | -- | Crop Science | 030 | si | 1 | 0.29 | 0.04 | 2001 |
| 8/28/1994 | 1047 | Crop Science | 108 | df | 1.0 | 0.310 | 0.220 | 1994 |
| 09/15/97 | 7:35 AM | Crop Science | 108 | DF | 0 | 0.21 | 0.13 | 1997 |
| 2001-2002 | -- | Crop Science | 108 | df | 0 | 0.01 | 0.06 | 2001 |
| 09/15/97 | 7:25 AM | Crop Science | 130 | sink | 0 | 0.71 | 0.01 | 1997 |
| 2001-2002 | -- | Crop Science | 130 | si | 2 | 0.73 | 0.02 | 2001 |
| 09/15/97 | 7:30 AM | Crop Science | 155 | sink | 0 | 0.65 | 0.78 | 1997 |
| 2001-2002 | -- | Crop Science | 155 | si | 1 | 0.43 | 0.33 | 2001 |
| 09/15/97 | 7:15 AM | Crop Science | 208 | DF | 21 | 0.22 | 0.16 | 1997 |
| 10/27/97 | 6:35 AM | Crop Science | 208 | DF | 1 | 0.47 | 0.48 | 1997 |
| 2001-2002 | -- | Crop Science | 208 | df | 0 | 0.01 | 0.02 | 2001 |
| 09/15/97 | 7:17 AM | Crop Science | 230 | sink | 0 | 0.68 | 0.29 | 1997 |

OSU Drinking Water Sampling Results - 1988:2005

9/7/2016

During sampling, if the EPA action level was exceeded for lead, mandatory repairs were typically made to the water supply system (replacing piping and/or fixtures). NT = not tested. ND = not detected

Action level or maximum contaminant level

15

1.3

0.3

| Date | Time | Building | Room/ Location | Source | Lead (ug/L) | Copper (mg/L) | Iron (mg/L) | year |
|------------|---------|----------------------|----------------|--------|-------------|---------------|-------------|------|
| 2001-2002 | -- | Crop Science | 230 | si | 0 | 0.83 | 0.02 | 2001 |
| 8/28/1994 | 1053 | Crop Science | 308 | df | 1.0 | 0.400 | 0.260 | 1994 |
| 09/15/97 | 7:11 AM | Crop Science | 308 | DF | 0 | 0.37 | 0.24 | 1997 |
| 2001-2002 | -- | Crop Science | 308 | df | 0 | 0.01 | 0.01 | 2001 |
| 09/15/97 | 7:13 AM | Crop Science | 350 | sink | 22 | 0.40 | 0.60 | 1997 |
| 10/27/97 | 6:30 AM | Crop Science | 350 | sink | 4 | 0.21 | 0.55 | 1997 |
| 2001-2002 | -- | Crop Science | 350 | si | 1 | 0.54 | 0.17 | 2001 |
| 09/15/97 | 7:09 AM | Crop Science | 408 | DF | 0 | 0.63 | 0.18 | 1997 |
| 2001-2002 | -- | Crop Science | 408 | df | 0 | 0.02 | 0.01 | 2001 |
| 1995 | -- | Dairy Barn | LAB | SI | 0 | 0.01 | 0.01 | 1905 |
| 1995 | -- | Dairy Milking Parlor | milk room | SI | 1 | 0.01 | 0.01 | 1905 |
| 1995 | -- | Dawes House | 012 | SI | 0 | 0.02 | 0.3 | 1905 |
| 1995 | -- | Dawes House | 024 | SI | 1 | 0.44 | >3.30 | 1905 |
| 1/12/2000 | -- | Dawes House | Bath | Sink | 0 | 0.02 | 0.42 | 2000 |
| 1/12/2000 | -- | Dawes House | Kitchen | Sink | 1 | 0.01 | 0.38 | 2000 |
| 12/13/1994 | 0700 | Dearborn | 007 | df | 5.0 | NT | NT | 1994 |
| 12/13/1994 | 0702 | Dearborn | 106 | df | 5.0 | NT | NT | 1994 |
| 1995 | -- | Dearborn | 106 | DF | 7 | 0.05 | 1.49 | 1905 |
| 8/25/1994 | 0754 | Dearborn | 112 | df | 18.0 | 0.010 | 0.370 | 1994 |
| 12/13/1994 | 0704 | Dearborn | 203 | df | 0.1 | NT | NT | 1994 |
| 1995 | -- | Dearborn | 203 | DF | 1 | 0.03 | 1 | 1905 |
| 8/25/1994 | 0759 | Dearborn | 302 | df | 10.0 | 0.001 | 0.710 | 1994 |
| 12/13/1994 | 0706 | Dearborn | 302 | df | 5.0 | NT | NT | 1994 |
| 1995 | -- | Dearborn | 302 | DF | 16 | 0.04 | 1.18 | 1905 |
| 1995 | -- | Dearborn | 303F | SI | 7 | 0.01 | 0.27 | 1905 |
| 1995 | -- | Dearborn | 309 | DF | 13 | 0.01 | 0.18 | 1905 |
| 12/13/1994 | 0710 | Dearborn | 401 | df | 9.0 | NT | NT | 1994 |
| 10/12/1994 | 0732 | dixon rec | 181 | df | 1.0 | 1.300 | 0.010 | 1994 |
| 10/12/1994 | 0729 | dixon rec | 191 | df | 1.0 | 0.420 | 0.010 | 1994 |
| 8/28/1994 | 1023 | Dryden | 105 | df | 0.1 | 1.540 | 0.020 | 1994 |
| 1995 | -- | Dryden | 105 | DF | 0 | 2.12 | 0.03 | 1905 |
| 12/22/1999 | -- | Dryden | 105 | DF | 0 | 2.25 | 0.01 | 1999 |
| 1995 | -- | Dryden | 209 | DF | 0 | 2.15 | 0.02 | 1905 |
| 12/22/1999 | -- | Dryden | 209 | DF | 0 | 2.39 | 0.02 | 1999 |
| 12/22/1999 | -- | Dryden | 218 | Sink | 0 | 0.83 | 0.01 | 1999 |
| 12/22/1999 | -- | Dryden | 302 | Sink | 0 | 1.32 | 0.01 | 1999 |
| 8/28/1994 | 1027 | Dryden | 308 | df | 0.1 | 1.200 | 0.040 | 1994 |
| 1995 | -- | Dryden | 308 | DF | 0 | 1.72 | 0.02 | 1905 |
| 12/22/1999 | -- | Dryden | 308 | DF | 0 | 2.20 | 0.01 | 1999 |
| 9/28/1994 | 0714 | east greenhouse | 124 | si | 1.0 | 0.040 | 0.050 | 1994 |
| 8/30/1994 | 0719 | Education Hall | 105 | df | 7.0 | 0.080 | 1.330 | 1994 |
| 9/18/1996 | 7:51 AM | Education Hall | 105 | df | 0 | 0.05 | 1.13 | 1996 |
| 9/18/1996 | 7:56 AM | Education Hall | 210 | df | 0 | 0.01 | 0.67 | 1996 |
| 9/18/1996 | 7:57 AM | Education Hall | 216 | df | 0 | 0.35 | 1.25 | 1996 |
| 8/30/1994 | 0721 | Education Hall | 302 | df | 0.1 | 0.030 | 1.740 | 1994 |
| 9/18/1996 | 7:58 AM | Education Hall | 302 | df | 1 | 0.14 | 3.03 | 1996 |
| 9/18/1996 | 8:00 AM | Education Hall | 406 | df | 1 | 0.08 | 2.12 | 1996 |
| 10/4/1996 | 8:23 AM | F/S EMS shop | 108A | df | 1 | 0.84 | 0.00 | 1996 |
| 10/4/1996 | 7:58 AM | F/S heat plant | 100 | df | 0 | 0.32 | 0.51 | 1996 |
| 10/12/1994 | 0730 | F/S heat plant | 105 | df | 1.0 | 0.290 | 0.640 | 1994 |
| 10/4/1996 | 8:02 AM | F/S heat plant | 105 | sink | 0 | 0.18 | 0.00 | 1996 |
| 10/4/1996 | 8:30 AM | F/S key shop | 101 | sink | 1 | 0.12 | 1.91 | 1996 |
| 10/4/1996 | 8:06 AM | F/S metal shop | 107B | df | 1 | 0.74 | 0.91 | 1996 |
| 10/12/1994 | 0645 | F/S metal trades | 107 | df | 2.0 | 1.250 | 0.230 | 1994 |
| 10/4/1996 | 7:50 AM | F/S paint shop | 101 | df | 2 | 0.17 | 0.06 | 1996 |
| 10/12/1994 | 0740 | F/S shop breakroom | 104 | df | 1.0 | 0.340 | 0.220 | 1994 |

OSU Drinking Water Sampling Results - 1988:2005

9/7/2016

During sampling, if the EPA action level was exceeded for lead, mandatory repairs were typically made to the water supply system (replacing piping and/or fixtures). NT = not tested. ND = not detected

Action level or maximum contaminant level

15 1.3 0.3

| Date | Time | Building | Room/ Location | Source | Lead (ug/L) | Copper (mg/L) | Iron (mg/L) | year |
|------------|---------|---------------------|----------------|--------|-------------|---------------|-------------|------|
| 10/4/1996 | 8:08 AM | F/S shops N | break | df | 1 | 0.37 | 0.10 | 1996 |
| 10/4/1996 | 8:10 AM | F/S shops N | break | sink | 1 | 0.02 | 0.13 | 1996 |
| 10/4/1996 | 7:44 AM | F/S stores | 105B | sink | 1 | 0.01 | 0.01 | 1996 |
| 10/4/1996 | 7:42 AM | F/S stores | 106A | df | 9 | 0.45 | 0.03 | 1996 |
| 10/12/1994 | 0745 | F/S stores | 106C | df | 1.0 | 0.380 | 0.130 | 1994 |
| 10/27/97 | 7:40 AM | Fairbanks Annex | 117 | sink | 1 | 1.31 | 0.01 | 1997 |
| 10/27/97 | 7:20 AM | Fairbanks Hall | 106 | sink | 0 | 1.05 | 0.01 | 1997 |
| 2001-2002 | -- | Fairbanks Hall | 106 | si | 0 | 1.41 | 0.01 | 2001 |
| 8/30/1994 | 0834 | Fairbanks Hall | 111 | df | 1.0 | 0.910 | 0.150 | 1994 |
| 10/27/97 | 7:18 AM | Fairbanks Hall | 111 | DF | 1 | 1.06 | 0.01 | 1997 |
| 2001-2002 | -- | Fairbanks Hall | 111 | df | 1 | 0.68 | 0.01 | 2001 |
| 2001-2002 | -- | Fairbanks Hall | 117 | si | 0 | 0.88 | 0.07 | 2001 |
| 10/27/97 | 7:29 AM | Fairbanks Hall | 216 | DF | 0 | 1.73 | 0.01 | 1997 |
| 2001-2002 | -- | Fairbanks Hall | 216 | df | 0 | 0.47 | 0.01 | 2001 |
| 10/27/97 | 7:27 AM | Fairbanks Hall | 300 | DF | 0 | 1.16 | 0.09 | 1997 |
| 2001-2002 | -- | Fairbanks Hall | 300/320 | df | 0 | 1.06 | 0.01 | 2001 |
| 10/27/97 | 7:25 AM | Fairbanks Hall | 320 | DF | 1 | 1.79 | 0.01 | 1997 |
| 1995 | -- | Farm Service Shop | restroom | DF | 0 | 0.35 | 0.22 | 1905 |
| 1995 | -- | Farm Service Shop | restroom | SI | 1 | 0.04 | 0.46 | 1905 |
| 8/28/1994 | 1005 | forest research lab | 104 | df | 1.0 | 0.390 | 0.370 | 1994 |
| 8/28/1994 | 1008 | forest research lab | 204 | df | 1.0 | 0.510 | 0.280 | 1994 |
| 09/22/97 | 7:04 AM | Gilbert Addition | 009 | DF | 2 | 1.24 | 0.06 | 1997 |
| 2001-2002 | -- | Gilbert Addition | 009 | df | 2 | 0.8 | 0.08 | 2001 |
| 09/22/97 | 7:06 AM | Gilbert Addition | 101 | DF | 13 | 1.08 | 0.15 | 1997 |
| 2001-2002 | -- | Gilbert Addition | 101 | df | 1 | 0.7 | 0.09 | 2001 |
| 09/22/97 | 7:02 AM | Gilbert Addition | 209 | DF | 1 | 0.70 | 0.47 | 1997 |
| 8/25/1994 | 0701 | Gilbert Addition | 211 | df | 8.0 | 0.590 | 0.150 | 1994 |
| 09/22/97 | 6:59 AM | Gilbert Addition | 309 | DF | 1 | 0.92 | 0.41 | 1997 |
| 2001-2002 | -- | Gilbert Addition | 309 | df | 1 | 0.93 | 0.05 | 2001 |
| 09/22/97 | 6:58 AM | Gilbert Addition | 409 | DF | 1 | 0.89 | 0.67 | 1997 |
| 2001-2002 | -- | Gilbert Addition | 409 | df | 1 | 0.45 | 0.06 | 2001 |
| 8/25/1994 | 0655 | Gilbert Addition | 411 | df | 9.0 | 0.490 | 0.180 | 1994 |
| 09/22/97 | 8:00 AM | Gilbert Hall | 016 | DF | 0 | 0.06 | 0.49 | 1997 |
| 2001-2002 | -- | Gilbert Hall | 016 | df | 0 | 0.01 | 0.09 | 2001 |
| 09/22/97 | 6:41 AM | Gilbert Hall | 031 | DF | 0 | 0.16 | 0.68 | 1997 |
| 2001-2002 | -- | Gilbert Hall | 031 | df | 1 | 0.27 | 1.25 | 2001 |
| 09/22/97 | 6:32 AM | Gilbert Hall | 130 | DF | 1 | 0.65 | 0.22 | 1997 |
| 2001-2002 | -- | Gilbert Hall | 130 | df | 0 | 0.17 | 0.19 | 2001 |
| 8/25/1994 | 0645 | Gilbert Hall | 133 | df | 0.1 | 0.430 | 0.230 | 1994 |
| 09/22/97 | 6:35 AM | Gilbert Hall | 156 | sink | 1 | 0.66 | 0.14 | 1997 |
| 2001-2002 | -- | Gilbert Hall | 156 | si | 1 | 0.39 | 0.08 | 2001 |
| 2001-2002 | -- | Gilbert Hall | 209 | df | 1 | 0.81 | 0.06 | 2001 |
| 09/22/97 | 6:50 AM | Gilbert Hall | 216 | DF | 0 | 0.04 | 0.90 | 1997 |
| 2001-2002 | -- | Gilbert Hall | 216 | df | 0 | 0.01 | 0.15 | 2001 |
| 09/22/97 | 6:46 AM | Gilbert Hall | 232 | DF | 1 | 0.70 | 0.27 | 1997 |
| 2001-2002 | -- | Gilbert Hall | 232 | df | 0 | 0.15 | 0.54 | 2001 |
| 09/22/97 | 6:52 AM | Gilbert Hall | 322 | sink | 2 | 1.49 | 0.05 | 1997 |
| 2001-2002 | -- | Gilbert Hall | 322 | si | 0 | 0.95 | 0.02 | 2001 |
| 09/22/97 | 6:54 AM | Gilbert Hall | 328 | DF | 1 | 0.69 | 0.63 | 1997 |
| 2001-2002 | -- | Gilbert Hall | 328 | df | 0 | 4.11 | 0.67 | 2001 |
| 8/25/1994 | 0649 | Gilbert Hall | 333 | df | 0.1 | 0.480 | 0.380 | 1994 |
| 8/28/1994 | 0908 | gill | 138 | df | 1.0 | 0.010 | 0.750 | 1994 |
| 8/28/1994 | 0913 | gill | 212 | df | 1.0 | 0.010 | 0.100 | 1994 |
| 8/30/1994 | 0856 | gilmore annex | 102 | si | 3.0 | 0.010 | 0.350 | 1994 |
| 10/27/97 | 7:00 AM | Gilmore Annex | 104 | sink | 9 | 0.05 | 0.31 | 1997 |
| 2001-2002 | -- | Gilmore Annex | 104 | si | 1 | 0.02 | 0.86 | 2001 |

OSU Drinking Water Sampling Results - 1988:2005

9/7/2016

During sampling, if the EPA action level was exceeded for lead, mandatory repairs were typically made to the water supply system (replacing piping and/or fixtures). NT = not tested. ND = not detected

Action level or maximum contaminant level

15 1.3 0.3

| Date | Time | Building | Room/ Location | Source | Lead (ug/L) | Copper (mg/L) | Iron (mg/L) | year |
|------------|----------|-------------------|----------------|----------|-------------|---------------|-------------|------|
| 10/20/2000 | 12:10 PM | Gilmore hall | 0130 | DF | 3 | 0.02 | 0.66 | 2000 |
| 10/5/1994 | 0704 | Gilmore hall | 108 | df | 0.1 | 1.570 | 0.010 | 1994 |
| 10/27/97 | 7:05 AM | Gilmore hall | 122 | DF | 8 | 0.60 | 0.18 | 1997 |
| 2001-2002 | -- | Gilmore hall | 122 | df | 0 | 0.21 | 0.01 | 2001 |
| 10/27/97 | 7:10 AM | Gilmore hall | 211 | sink | 10 | 0.20 | 0.14 | 1997 |
| 2001-2002 | -- | Gilmore hall | 211 | si | 0 | 0.46 | 0.22 | 2001 |
| 8/30/1994 | 0849 | Gilmore hall | 230 | df | 1.0 | 0.020 | 1.670 | 1994 |
| 10/27/97 | 7:08 AM | Gilmore hall | 230 | DF | 9 | 0.01 | 0.60 | 1997 |
| 2001-2002 | -- | Gilmore hall | 230 | df | 1 | 0.03 | 0.05 | 2001 |
| 9/19/1996 | 7:33 AM | Gladys Valley gym | 018E | sink | 0 | 0.57 | 0.00 | 1996 |
| 10/12/1994 | 0720 | Gladys Valley gym | 100 | df | 1.0 | 1.850 | 0.020 | 1994 |
| 9/18/1996 | 8:07 AM | Gladys Valley gym | 100 | df | 1 | 1.40 | 0.01 | 1996 |
| 9/18/1996 | 8:10 AM | Gladys Valley gym | 101 | sink | 0 | 0.41 | 0.01 | 1996 |
| 12/13/1994 | 0645 | Gleeson | 004 | df | 5.0 | NT | NT | 1994 |
| 8/25/1994 | 0707 | Gleeson | 102 | df | 10.0 | 0.010 | 0.810 | 1994 |
| 12/13/1994 | 0646 | Gleeson | 102 | df | 1.0 | NT | NT | 1994 |
| 1995 | -- | Gleeson | 102 | DF | 4 | 0.05 | 0.74 | 1905 |
| 2/15/2004 | -- | Gleeson | 102 | DF | NT | 0.01 | 0.61 | 2004 |
| 8/25/1994 | 0710 | Gleeson | 102A | bt | 0.1 | 0.001 | 0.010 | 1994 |
| 1995 | -- | Gleeson | 200 | DF | 7 | 0.34 | 0.58 | 1905 |
| 12/13/1994 | 0650 | Gleeson | 202 | df | 11.0 | NT | NT | 1994 |
| 2/15/2004 | -- | Gleeson | 202 | DF | NT | 0.59 | 0.19 | 2004 |
| 8/25/1994 | 0714 | Gleeson | 304 | df | 14.0 | 0.020 | 0.400 | 1994 |
| 12/13/1994 | 0650 | Gleeson | 304 | df | 11.0 | NT | NT | 1994 |
| 1995 | -- | Gleeson | 304 | DF | 3 | 0.68 | 0.93 | 1905 |
| 2/15/2004 | -- | Gleeson | 304 | DF | NT | 0.43 | 0.17 | 2004 |
| 09/22/97 | 7:23 AM | Graf | 100 | DF | 5 | 0.92 | >3.3 | 1997 |
| 09/22/97 | 7:16 AM | Graf | 105 | sink | 1 | 0.61 | 0.04 | 1997 |
| 8/25/1994 | 0745 | graf | 206 | df | 1.0 | 0.560 | 1.070 | 1994 |
| 10/5/1994 | 0655 | hinsdale wave | 100 | si | 4.0 | 1.380 | 0.250 | 1994 |
| 10/26/2005 | -- | HMSC | Shop | ? | ND | ND | ND | 2005 |
| 10/26/2005 | -- | HMSC | Staff lounge | ? | 11.1 | 0.57 | 0.55 | 2005 |
| 10/26/2005 | -- | HMSC | Vol Library | ? | 10.3 | 0.21 | 4.47 | 2005 |
| 10/5/1994 | 0728 | Housing warehouse | 100 | df | 18.0 | 0.080 | 1.010 | 1994 |
| 1995 | -- | Housing warehouse | 100 | DF | 10 | 0.15 | 1.6 | 1905 |
| 1995 | -- | Housing warehouse | 100 | SI large | 1 | 0.06 | 0.34 | 1905 |
| 1995 | -- | Housing warehouse | 100 | SI small | 0 | 0.05 | 0.5 | 1905 |
| 8/30/1994 | 0727 | Kerr Admin | 130 | df | 1.0 | 0.060 | 0.210 | 1994 |
| 8/30/1994 | 0729 | Kerr Admin | 430 | df | 6.0 | 0.010 | 0.590 | 1994 |
| 8/30/1994 | 0732 | Kerr Admin | 630 | df | 11.0 | 0.010 | 0.320 | 1994 |
| 10/1/1996 | 7:54 AM | Kerr Admin | A010 | sink | 8 | 0.10 | 0.34 | 1996 |
| 12/15/1994 | 0645 | Kerr Admin | A110 | df | 1.0 | NT | NT | 1994 |
| 9/24/1996 | 7:19 AM | Kerr Admin | A110 | df | 2 | 0.13 | 0.28 | 1996 |
| 10/1/1996 | 7:37 AM | Kerr Admin | A200K | sink | 9 | 0.02 | 0.34 | 1996 |
| 12/15/1994 | 0646 | Kerr Admin | A218 | df | 3.0 | NT | NT | 1994 |
| 9/24/1996 | 7:24 AM | Kerr Admin | A218 | df | 8 | 0.17 | 0.44 | 1996 |
| 10/1/1996 | 7:38 AM | Kerr Admin | A222G | sink | 6 | 0.29 | 0.14 | 1996 |
| 10/1/1996 | 7:35 AM | Kerr Admin | A302 | sink | 9 | 0.01 | 0.17 | 1996 |
| 10/12/1994 | 0715 | Kerr Admin | A312 | df | 2.0 | 0.200 | 0.270 | 1994 |
| 12/15/1994 | 0647 | Kerr Admin | A312 | df | 3.0 | NT | NT | 1994 |
| 9/24/1996 | 7:28 AM | Kerr Admin | A312 | df | 3 | 0.12 | 0.16 | 1996 |
| 10/1/1996 | 7:32 AM | Kerr Admin | A322N | sink | 13 | 0.06 | 1.15 | 1996 |
| 10/12/1994 | 0710 | Kerr Admin | A416 | df | 2.0 | 0.160 | 0.270 | 1994 |
| 12/15/1994 | 0648 | Kerr Admin | A416 | df | 1.0 | NT | NT | 1994 |
| 9/24/1996 | 7:24 AM | Kerr Admin | A416 | df | 1 | 0.18 | 0.71 | 1996 |
| 9/24/1996 | 7:25 AM | Kerr Admin | A416C | si | 9 | 0.07 | 1.14 | 1996 |

OSU Drinking Water Sampling Results - 1988:2005

9/7/2016

During sampling, if the EPA action level was exceeded for lead, mandatory repairs were typically made to the water supply system (replacing piping and/or fixtures). NT = not tested. ND = not detected

Action level or maximum contaminant level

15

1.3

0.3

| Date | Time | Building | Room/ Location | Source | Lead (ug/L) | Copper (mg/L) | Iron (mg/L) | year |
|------------|---------|----------------------|----------------|--------|-------------|---------------|-------------|------|
| 10/1/1996 | 7:30 AM | Kerr Admin | A422F | sink | 23 | 0.05 | 1.27 | 1996 |
| 10/1/1996 | 7:18 AM | Kerr Admin | A500F | sink | 14 | 0.02 | 0.56 | 1996 |
| 10/12/1994 | 0705 | Kerr Admin | A510 | df | 23.0 | 0.250 | 0.610 | 1994 |
| 12/15/1994 | 0650 | Kerr Admin | A510 | df | 1.0 | NT | NT | 1994 |
| 9/24/1996 | 7:22 AM | Kerr Admin | A510 | df | 3 | 0.18 | 0.23 | 1996 |
| 10/1/1996 | 7:20 AM | Kerr Admin | A510 | sink | 7 | 0.06 | 0.17 | 1996 |
| 10/1/1996 | 7:17 AM | Kerr Admin | A524E | sink | 4 | 0.01 | 0.19 | 1996 |
| 12/15/1994 | 0651 | Kerr Admin | A600 | df | 3.0 | NT | NT | 1994 |
| 9/24/1996 | 7:21 AM | Kerr Admin | A602 | df | 4 | 0.30 | 0.12 | 1996 |
| 10/1/1996 | 7:22 AM | Kerr Admin | A616 | sink | 2 | 0.01 | 0.10 | 1996 |
| 10/1/1996 | 7:20 AM | Kerr Admin | A648 | sink | 8 | 0.01 | 0.47 | 1996 |
| 10/12/1994 | 0659 | Kerr Admin | B004 | df | 1.0 | 1.520 | 0.030 | 1994 |
| 9/24/1996 | 7:21 AM | Kerr Admin | B004 | df | 0 | 0.96 | 0.01 | 1996 |
| 10/1/1996 | 7:50 AM | Kerr Admin | B020 | sink | 0 | 1.02 | 0.04 | 1996 |
| 10/1/1996 | 7:53 AM | Kerr Admin | B094 | sink | 1 | 0.46 | 0.04 | 1996 |
| 10/1/1996 | 7:46 AM | Kerr Admin | B100D | sink | 0 | 0.26 | 0.09 | 1996 |
| 10/1/1996 | 7:48 AM | Kerr Admin | B102H | sink | 1 | 0.20 | 0.02 | 1996 |
| 10/12/1994 | 0655 | Kerr Admin | B106 | df | 1.0 | 1.390 | 0.020 | 1994 |
| 9/24/1996 | 7:17 AM | Kerr Admin | B106 | df | 0 | 0.57 | 0.00 | 1996 |
| 10/1/1996 | 7:40 AM | Kerr Admin | B204K | sink | 0 | 0.35 | 0.02 | 1996 |
| 10/1/1996 | 7:42 AM | Kerr Admin | B206 | sink | 1 | 0.96 | 0.01 | 1996 |
| 8/9/2000 | -- | Kidder | 0042 | DF | 0 | 0.14 | 2.49 | 2000 |
| 12/21/1998 | 7:15 | Kidder | 042 | DF | 0 | 0.06 | 1.80 | 1998 |
| 12/21/1998 | 7:10 | Kidder | 088 | DF | 1 | 0.55 | 0.33 | 1998 |
| 12/15/1998 | 9:10 | Kidder | 100 | DF | 0 | 0.17 | 2.58 | 1998 |
| 12/20/1994 | 0740 | kidder | 128 | df | 4.0 | NT | NT | 1994 |
| 12/15/1998 | 9:00 | Kidder | 128 | DF | 3 | 0.16 | 0.50 | 1998 |
| 12/20/1994 | 0748 | kidder | 242 | df | 1.0 | NT | NT | 1994 |
| 12/15/1998 | 9:05 | Kidder | 252 | DF | 2 | 0.34 | 0.34 | 1998 |
| 12/20/1994 | 0745 | kidder | 336 | df | 1.0 | NT | NT | 1994 |
| 12/15/1998 | 9:05 | Kidder | 336 | DF | 3 | 2.24 | 0.25 | 1998 |
| 12/21/1998 | 7:15 | Kidder | 336 | DF | 4 | 0.51 | 1.09 | 1998 |
| 1995 | -- | Lab Animal Resource | 100 | SI | 0 | 0.94 | 1.01 | 1905 |
| 8/28/1994 | 1035 | Lab Animal Resource | 101 | df | 1.0 | 1.090 | 0.030 | 1994 |
| 1995 | -- | Lab Animal Resource | 101 | DF | 11 | 1.23 | 0.11 | 1905 |
| 8/30/1994 | 0806 | Langton | 017 | df | 15.0 | 0.010 | 0.400 | 1994 |
| 12/15/1994 | 0630 | Langton | 017 | df | 3.0 | NT | NT | 1994 |
| 9/19/1996 | 7:56 AM | Langton | 017 | df | 11 | 0.02 | 0.69 | 1996 |
| 12/15/1994 | 0637 | Langton | 018 | df | 4.0 | NT | NT | 1994 |
| 9/19/1996 | 7:58 AM | Langton | 018 | df | 5 | 0.04 | 0.42 | 1996 |
| 12/15/1994 | 0631 | Langton | 124A | df | 1.0 | NT | NT | 1994 |
| 9/19/1996 | 7:47 AM | Langton | 124A | df | 0 | 0.53 | 0.92 | 1996 |
| 12/15/1994 | 0632 | Langton | 131 | df | 1.0 | NT | NT | 1994 |
| 9/19/1996 | 7:48 AM | Langton | 138 | df | 1 | 0.79 | 0.26 | 1996 |
| 9/19/1996 | 7:50 AM | Langton | 221 | sink | 1 | 0.72 | 0.87 | 1996 |
| 9/19/1996 | 7:52 AM | Langton | 301 | df | 1 | 0.04 | 0.67 | 1996 |
| 9/19/1996 | 7:54 AM | Langton | 302 | sink | 1 | 0.11 | 0.32 | 1996 |
| 8/30/1994 | 0800 | langton | 310 | df | 4.0 | 0.070 | 0.590 | 1994 |
| 12/17/1998 | 6:45 | lasells stewart cntr | 100 | DF | 0 | 1.36 | 0.10 | 1998 |
| 10/5/1994 | 0807 | lasells stewart cntr | 104 | df | 1.0 | 1.580 | 0.020 | 1994 |
| 12/17/1998 | 6:50 | lasells stewart cntr | 104 | DF | 0 | 0.52 | 0.01 | 1998 |
| 12/17/1998 | 6:50 | lasells stewart cntr | 106 | DF | 0 | 1.39 | 0.08 | 1998 |
| 12/17/1998 | 6:47 | lasells stewart cntr | 113 | sink | 0 | 0.33 | 0.25 | 1998 |
| 12/17/1998 | 6:50 | lasells stewart cntr | 117 | DF | 0 | 1.15 | 0.06 | 1998 |
| 10/5/1994 | 0812 | lasells stewart cntr | 142 | df | 1.0 | 1.690 | 0.050 | 1994 |
| 12/17/1998 | 6:52 | lasells stewart cntr | 147 | DF | 0 | 1.31 | 0.07 | 1998 |

OSU Drinking Water Sampling Results - 1988:2005

9/7/2016

During sampling, if the EPA action level was exceeded for lead, mandatory repairs were typically made to the water supply system (replacing piping and/or fixtures). NT = not tested. ND = not detected

Action level or maximum contaminant level

15 1.3 0.3

| Date | Time | Building | Room/ Location | Source | Lead (ug/L) | Copper (mg/L) | Iron (mg/L) | year |
|------------|---------|-----------------|----------------|--------|-------------|---------------|-------------|------|
| 8/28/1994 | 0923 | magruder | 106 | df | 0.1 | 0.500 | 0.010 | 1994 |
| 1995 | -- | Magruder | 106 | DF | 1 | 0.73 | 0.09 | 1905 |
| 1995 | -- | Magruder | 108 | SI | 0 | 0.38 | 0.01 | 1905 |
| 1995 | -- | Magruder | 132 | DF | 0 | 0.11 | 0.03 | 1905 |
| 1995 | -- | Magruder | 201 | DF | 0 | 0.98 | 0.11 | 1905 |
| 1995 | -- | Magruder | 229 | SI | 1 | 0.58 | 0.1 | 1905 |
| 8/28/1994 | 0926 | magruder | 239 | df | 2.0 | 0.760 | 0.250 | 1994 |
| 1995 | -- | Magruder | 239 | DF | 1 | 0.89 | 0.18 | 1905 |
| 9/24/1996 | 7:34 AM | McAl Fieldhouse | 112 | sink | 0 | 0.22 | 0.10 | 1996 |
| 9/24/1996 | 7:46 AM | McAl Fieldhouse | 211 | sink | 0 | 0.13 | 0.12 | 1996 |
| 11/29/1994 | 1010 | McAl Fieldhouse | 304 | df | 5.0 | 0.080 | 0.180 | 1994 |
| 9/24/1996 | 7:41 AM | McAl Fieldhouse | 305 | df | 1 | 0.02 | 0.07 | 1996 |
| 10/12/1994 | 0705 | memorial union | 029 | df | 4.0 | 1.070 | 0.070 | 1994 |
| 12/28/1998 | 7:00 | Memorial Union | 035 | sink | 0 | 0.62 | 0.08 | 1998 |
| 10/12/1994 | 0717 | memorial union | 050 | df | 1.0 | 0.330 | 0.340 | 1994 |
| 12/28/1998 | 6:50 | Memorial Union | 111 | DF | 1 | 1.08 | 1.12 | 1998 |
| 12/28/1998 | 6:54 | Memorial Union | 1st floor east | DF | 0 | 1.62 | 0.04 | 1998 |
| 12/28/1998 | 6:55 | Memorial Union | 1st floor west | DF | 0 | 1.56 | 0.03 | 1998 |
| 12/28/1998 | 6:45 | Memorial Union | 200 | DF | 0 | 2.15 | 0.05 | 1998 |
| 12/28/1998 | 7:12 | Memorial Union | basemnt shop | sink | 1 | 0.33 | 3.30 | 1998 |
| 12/28/1998 | 7:10 | Memorial Union | bookstore | DF | 0 | 1.27 | 0.09 | 1998 |
| 12/28/1998 | 7:07 | Memorial Union | west ballroom | DF | 2 | 1.32 | 0.02 | 1998 |
| 12/21/1998 | 7:30 | Merryfield | 101 | sink | 17 | 0.01 | 0.02 | 1998 |
| 8/30/1994 | 0633 | merryfield | 110 | df | 3.0 | 0.470 | 0.230 | 1994 |
| 12/21/1998 | 7:30 | Merryfield | 110 | DF | 1 | 0.29 | 0.26 | 1998 |
| 12/21/1998 | 7:30 | Merryfield | 110A | sink | 1 | 0.21 | 2.70 | 1998 |
| 8/25/1994 | 0824 | merryfield | 202 | df | 0.1 | 0.010 | 1.210 | 1994 |
| 12/21/1998 | 7:27 | Merryfield | 202 | DF | 0 | 0.01 | 0.64 | 1998 |
| 12/17/1998 | 7:20 | Milam | 011A | DF | 41 | 0.51 | 0.75 | 1998 |
| 12/17/1998 | 7:25 | Milam | 016 | DF | 0 | 1.20 | 0.01 | 1998 |
| 12/17/1998 | 7:16 | Milam | 025 | DF | 1 | 1.16 | 0.01 | 1998 |
| 8/23/1994 | 0755 | milam | 117B | df | 0.1 | 1.010 | 0.010 | 1994 |
| 12/17/1998 | 7:21 | Milam | 117B | DF | 0 | 0.84 | 0.01 | 1998 |
| 12/17/1998 | 7:15 | Milam | 129 | DF | 0 | 0.87 | 0.01 | 1998 |
| 12/17/1998 | 7:29 | Milam | 148 | sink | 1 | 0.93 | 0.66 | 1998 |
| 12/17/1998 | 7:13 | Milam | 211 | DF | 0 | 0.36 | 0.01 | 1998 |
| 12/17/1998 | 7:15 | Milam | 215 | DF | 0 | 0.91 | 0.51 | 1998 |
| 12/17/1998 | 7:15 | Milam | 221 | DF | 0 | 0.84 | 0.01 | 1998 |
| 12/17/1998 | 7:10 | Milam | 317A | DF | 1 | 0.43 | 0.01 | 1998 |
| 8/23/1994 | 0747 | milam | 331 | df | 2.0 | 0.140 | 0.110 | 1994 |
| 12/17/1998 | 7:12 | Milam | 331 | DF | 1 | 0.47 | 0.16 | 1998 |
| 12/21/1998 | 7:13 | Milne | 111 | sink | 12 | 1.22 | 0.06 | 1998 |
| 12/21/1998 | 7:07 | Milne | 120 | DF | 0 | 1.50 | 0.02 | 1998 |
| 12/15/1998 | 8:55 | Milne | 211 | DF | 1 | 0.45 | 0.01 | 1998 |
| 8/30/1994 | 0657 | milne | 212 | df | 1.0 | 0.170 | 0.440 | 1994 |
| 8/30/1994 | 0813 | moreland | 128 | df | 6.0 | 0.450 | 0.310 | 1994 |
| 9/19/1996 | 7:38 AM | Moreland | 128 | df | 0 | 0.47 | 0.37 | 1996 |
| 7/29/2004 | | Moreland | 128 | DF | 0 | 0.37 | 0.14 | 2004 |
| 8/30/1994 | 0820 | moreland | 216 | df | 1.0 | 0.370 | 0.350 | 1994 |
| 9/19/1996 | 7:40 AM | Moreland | 218 | df | 1 | 0.32 | 0.33 | 1996 |
| 7/29/2004 | | Moreland | 218 | DF | 1 | 0.35 | 0.29 | 2004 |
| 9/19/1996 | 7:42 AM | Moreland | 362 | df | 0 | 0.31 | 0.45 | 1996 |
| 7/29/2004 | | Moreland | 362 | DF | NT | 0.35 | 0.70 | 2004 |
| 10/5/1994 | 0647 | motor pool | 100 | df | 3.0 | 1.530 | 0.010 | 1994 |
| 12/16/1998 | 6:50 | Motor Pool | 100 | DF | 1 | 1.68 | 0.01 | 1998 |
| 12/16/1998 | 6:50 | Motor Pool | 100A | sink | 0 | 0.08 | 0.46 | 1998 |

OSU Drinking Water Sampling Results - 1988:2005

9/7/2016

During sampling, if the EPA action level was exceeded for lead, mandatory repairs were typically made to the water supply system (replacing piping and/or fixtures). NT = not tested. ND = not detected

Action level or maximum contaminant level

15 1.3 0.3

| Date | Time | Building | Room/ Location | Source | Lead (ug/L) | Copper (mg/L) | Iron (mg/L) | year |
|------------|---------|-----------------|-------------------|--------|-------------|---------------|-------------|------|
| 9/28/1994 | 0755 | nash | 012 | df | 6.0 | 0.120 | 0.010 | 1994 |
| 12/21/1998 | 8:01 | Nash | 012 | DF | 13 | 0.13 | 0.02 | 1998 |
| 12/21/1998 | 8:00 | Nash | 054 | DF | 3 | 1.54 | 0.02 | 1998 |
| 12/16/1998 | 7:45 | Nash | 138 | DF | 0 | 0.90 | 0.01 | 1998 |
| 12/16/1998 | 7:45 | Nash | 138 | DF | 1 | 0.90 | 0.01 | 1998 |
| 12/16/1998 | 7:40 | Nash | 208 | DF | 1 | 0.46 | 0.01 | 1998 |
| 12/16/1998 | 7:45 | Nash | 232 | DF | 1 | 0.94 | 0.01 | 1998 |
| 12/16/1998 | 7:45 | Nash | 306 | DF | 0 | 0.47 | 0.01 | 1998 |
| 12/16/1998 | 7:43 | Nash | 336 | DF | 0 | 1.56 | 0.01 | 1998 |
| 12/16/1998 | 7:37 | Nash | 408 | DF | 0 | 0.40 | 0.01 | 1998 |
| 9/28/1994 | 0752 | nash | 436 | df | 0.1 | 0.630 | 0.001 | 1994 |
| 12/16/1998 | 7:35 | Nash | 438 | DF | 1 | 0.85 | 0.01 | 1998 |
| 12/16/1998 | 7:40 | Nash | 504 | DF | 0 | 0.47 | 0.01 | 1998 |
| 9/28/1994 | 0750 | nash | 536 | df | 0.1 | 1.670 | 0.010 | 1994 |
| 12/16/1998 | 7:37 | Nash | 536 | DF | 0 | 1.93 | 0.01 | 1998 |
| 11/29/1994 | 1005 | Nav Armory | 114 | df | 1.0 | 0.080 | 0.210 | 1994 |
| 9/26/1996 | 7:15 AM | Nav Armory | 114 | df | 1 | 0.07 | 0.24 | 1996 |
| 9/26/1996 | 7:15 AM | Nav Armory | 120 | sink | 5 | 0.01 | 0.26 | 1996 |
| 9/28/1994 | 0657 | ocean admin | 107 | si | 1.0 | 0.170 | 1.820 | 1994 |
| 12/17/1998 | 7:00 | ocean admin | 107 | sink | 1 | 0.16 | 0.01 | 1998 |
| 12/17/1998 | 7:03 | ocean admin | 209 | DF | 0 | 0.94 | 0.01 | 1998 |
| 1995 | -- | Ocean Staging | 100 | SI | 8 | 0.06 | 1.03 | 1905 |
| 12/22/1999 | -- | Ocean Staging | 101 | Sink | 7 | 0.02 | 0.52 | 1999 |
| 1995 | -- | Old Asian CC | 100 | SI | 4 | 0.15 | 1.17 | 1905 |
| 1995 | -- | Old Asian CC | 100 | SI | 18 | 0.05 | 0.48 | 1905 |
| 10/12/1994 | 0818 | Old hispanic CC | 100 | si | 0.1 | 0.001 | 0.040 | 1994 |
| 8/30/1994 | 0827 | Old N Am LH | 002 | si | 0.1 | 0.430 | 0.070 | 1994 |
| 9/19/1996 | 8:12 AM | Old N Am LH | 002 | sink | 0 | 0.39 | 0.06 | 1996 |
| 7/30/2004 | | Old N Am LH | 002 | Sink | 1 | 0.73 | 0.01 | 2004 |
| 12/15/1998 | -- | orchard court | 104 kitchen | sink | NT | 0.08 | 0.03 | 1998 |
| 12/15/1998 | -- | orchard court | 121 kitchen | sink | NT | 0.05 | 0.09 | 1998 |
| 12/15/1998 | -- | orchard court | 158 kitchen | sink | NT | 0.25 | 1.31 | 1998 |
| 12/15/1998 | -- | orchard court | 33 kitchen | sink | NT | 0.23 | 0.55 | 1998 |
| 12/15/1998 | -- | orchard court | 3340 kitchen | sink | NT | 0.11 | 0.06 | 1998 |
| 12/15/1998 | -- | orchard court | comm cntr kitchen | sink | NT | 0.01 | 0.01 | 1998 |
| 8/30/1994 | 0637 | Owen Hall (ECE) | 107 | df | 1.0 | 1.080 | 0.010 | 1994 |
| 11/03/97 | 7:18 AM | Owen Hall (ECE) | 107 | DF | 0 | 1.37 | 0.04 | 1997 |
| 2001-2002 | -- | Owen Hall (ECE) | 107 | df | 0 | 0.7 | 0.02 | 2001 |
| 11/03/97 | 7:20 AM | Owen Hall (ECE) | 222 | DF | 0 | 1.64 | 0.04 | 1997 |
| 2001-2002 | -- | Owen Hall (ECE) | 222 | df | 0 | 0.5 | 0.03 | 2001 |
| 11/03/97 | 7:21 AM | Owen Hall (ECE) | 224 | sink | 7 | 1.36 | 0.02 | 1997 |
| 8/30/1994 | 0641 | Owen Hall (ECE) | 320 | df | 0.1 | 0.910 | 0.020 | 1994 |
| 11/03/97 | 7:22 AM | Owen Hall (ECE) | 320 | DF | 0 | 1.45 | 0.04 | 1997 |
| 2001-2002 | -- | Owen Hall (ECE) | 320 | df | 0 | 0.3 | 0.03 | 2001 |
| 11/03/97 | 7:27 AM | Owen Hall (ECE) | 324 | sink | 9 | 1.32 | 0.05 | 1997 |
| 11/03/97 | 7:29 AM | Owen Hall (ECE) | 420 | DF | 1 | 1.18 | 0.02 | 1997 |
| 2001-2002 | -- | Owen Hall (ECE) | 420 | df | 0 | 0.77 | 0.04 | 2001 |
| 11/03/97 | 7:31 AM | Owen Hall (ECE) | 424 | sink | 0 | 0.26 | 0.03 | 1997 |
| 1995 | -- | Parker Stadium | 402 | DF | 1 | 1.69 | 0.06 | 1905 |
| 1995 | -- | Parker Stadium | 101 | SI | 10 | 0.02 | 0.35 | 1905 |
| 1995 | -- | Parker Stadium | 401 | SI | 8 | 2.24 | 0.04 | 1905 |
| 1995 | -- | Parker Stadium | 501 | SI | 5 | 1.11 | 0.07 | 1905 |
| 1995 | -- | Parker Stadium | climb cntr | SI | 2 | 0.15 | 0.38 | 1905 |
| 1995 | -- | Parker Stadium | concourse NW | DF | 4 | 0.05 | 0.42 | 1905 |
| 1995 | -- | Parker Stadium | concourse SW | DF | 0 | 0.01 | 0.18 | 1905 |

OSU Drinking Water Sampling Results - 1988:2005

9/7/2016

During sampling, if the EPA action level was exceeded for lead, mandatory repairs were typically made to the water supply system (replacing piping and/or fixtures). NT = not tested. ND = not detected

| Action level or maximum contaminant level | | | | | 15 | 1.3 | 0.3 | |
|---|---------|-----------------|----------------|--------|-------------|---------------|-------------|------|
| Date | Time | Building | Room/ Location | Source | Lead (ug/L) | Copper (mg/L) | Iron (mg/L) | year |
| 10/4/1996 | 8:18 AM | Parking service | 101A | sink | 1 | 0.10 | 0.13 | 1996 |
| 10/4/1996 | 8:14 AM | Parking service | 103 | df | 20 | 2.34 | >3.3 | 1996 |
| 9/28/1994 | 0812 | peavy | 066 | df | 1.0 | 0.980 | 0.010 | 1994 |
| 10/4/1996 | 8:51 AM | Peavy | 070 | PRE | 27 | 0.28 | 2.71 | 1996 |
| 10/4/1996 | 8:50 AM | Peavy | 070 | RO | 20 | 0.78 | >3.3 | 1996 |
| 12/21/1998 | 7:50 | Peavy | A066 | DF | 0 | 1.05 | 0.01 | 1998 |
| 12/21/1998 | 7:50 | Peavy | A142 | DF | 29 | 0.21 | 0.01 | 1998 |
| 12/21/1998 | 7:45 | Peavy | A147 | sink | 1 | 0.01 | 0.01 | 1998 |
| 12/21/1998 | 7:55 | Peavy | A270 | DF | 0 | 1.08 | 0.04 | 1998 |
| 9/18/1996 | 7:36 AM | Pharmacy | 115 | sink | 0 | 0.76 | 0.01 | 1996 |
| 7/30/2004 | | Pharmacy | 115 | Sink | NT | 0.89 | 0.01 | 2004 |
| 8/30/1994 | 0710 | pharmacy | 151 | df | 0.1 | 0.640 | 0.010 | 1994 |
| 9/18/1996 | 7:30 AM | Pharmacy | 151 | df | 0 | 0.82 | 0.01 | 1996 |
| 7/30/2004 | | Pharmacy | 151 | DF | NT | 0.45 | 0.01 | 2004 |
| 9/18/1996 | 7:40 AM | Pharmacy | 214A | sink | 0 | 0.56 | 0.01 | 1996 |
| 7/30/2004 | | Pharmacy | 214A | Sink | NT | 0.12 | 0.01 | 2004 |
| 9/18/1996 | 7:41 AM | Pharmacy | 237 | df | 1 | 0.52 | 0.01 | 1996 |
| 7/30/2004 | | Pharmacy | 237 | Sink | NT | 1.18 | 0.01 | 2004 |
| 9/18/1996 | 7:44 AM | Pharmacy | 301 | df | 0 | 1.97 | 0.01 | 1996 |
| 7/30/2004 | | Pharmacy | 301 | DF | 0 | 1.02 | 0.01 | 2004 |
| 8/30/1994 | 0714 | pharmacy | 405 | df | 2.0 | 0.820 | 0.010 | 1994 |
| 9/18/1996 | 7:46 AM | Pharmacy | 405 | df | 2 | 0.80 | 0.02 | 1996 |
| 7/30/2004 | | Pharmacy | 405 | DF | 1 | 0.52 | 0.01 | 2004 |
| 12/22/1998 | 7:37 | Plageman | 105 | sink | 1 | 0.24 | 0.14 | 1998 |
| 9/28/1994 | 0648 | plageman | 109A | df | 1.0 | 0.720 | 0.140 | 1994 |
| 12/22/1998 | 7:39 | Plageman | 109A | DF | 1 | 1.41 | 0.02 | 1998 |
| 9/28/1994 | 0650 | plageman | 207A | df | 1.0 | 0.760 | 0.260 | 1994 |
| 12/22/1998 | 7:47 | Plageman | 208A | DF | 0 | 1.42 | 0.03 | 1998 |
| 12/22/1998 | 7:42 | Plageman | 316 | DF | 0 | 1.37 | 0.02 | 1998 |
| 12/22/1998 | 7:43 | Plageman | 318 | sink | 0 | 0.70 | 0.01 | 1998 |
| 10/18/1994 | 0810 | Rad Cntr | A148 | df | 13.0 | 0.070 | 0.270 | 1994 |
| 12/18/1998 | 7:16 | Rad Cntr | A148 | DF | 6 | 0.15 | 0.11 | 1998 |
| 10/18/1994 | 0813 | Rad Cntr | C110 | df | 1.0 | 0.150 | 0.120 | 1994 |
| 12/18/1998 | 7:14 | Rad Cntr | C110 | DF | 1 | 0.22 | 0.44 | 1998 |
| 12/18/1998 | 8:00 | Rad Cntr | C112 | sink | 0 | 0.07 | 1.82 | 1998 |
| 12/18/1998 | 8:30 | Rad Cntr | D208 | DF | 7 | 0.44 | 0.22 | 1998 |
| 12/15/1998 | 8:45 | Rogers | 106 | DF | 1 | 1.24 | 0.01 | 1998 |
| 12/21/1998 | 7:18 | Rogers | 204A | sink | 2 | 0.55 | 0.03 | 1998 |
| 8/25/1994 | 0732 | rogers | 206 | df | 1.0 | 0.750 | 0.010 | 1994 |
| 12/15/1998 | 8:40 | Rogers | 206 | DF | 0 | 1.00 | 0.01 | 1998 |
| 12/21/1998 | 7:20 | Rogers | 304 | sink | 8 | 0.50 | 0.10 | 1998 |
| 12/15/1998 | 8:46 | Rogers | 310 | DF | 1 | 1.48 | 0.01 | 1998 |
| 8/25/1994 | 0736 | rogers | 410 | df | 0.1 | 1.260 | 0.090 | 1994 |
| 12/15/1998 | 8:50 | Rogers | 412 | DF | 0 | 1.72 | 0.01 | 1998 |
| 10/12/1994 | 0652 | Seed Lab | 104 | df | 1.0 | 0.460 | 0.130 | 1994 |
| 12/16/1998 | 6:45 | Seed Lab | 104 | DF | 0 | 0.15 | 0.01 | 1998 |
| 12/16/1998 | 6:45 | Seed Lab | 105 | sink | 0 | 0.23 | 0.01 | 1998 |
| 12/16/1998 | 6:50 | Seed Lab | 200 | sink | 0 | 0.61 | 0.01 | 1998 |
| 9/17/1996 | 8:10 AM | Shepard | 001 | sink | 0 | 0.12 | 1.98 | 1996 |
| 7/30/2004 | | Shepard | 001 | Sink | NT | 0.21 | 0.34 | 2004 |
| 8/25/1994 | 0724 | shepard | 101 | df | 1.0 | 0.280 | 0.390 | 1994 |
| 7/30/2004 | | Shepard | 101 | DF | 0 | 0.22 | 0.22 | 2004 |
| 9/17/1996 | 8:00 AM | Shepard | 101 | df | 1 | 0.27 | 0.35 | 1996 |
| 7/30/2004 | | Shepard | 103 | Sink | NT | 0.09 | 1.21 | 2004 |
| 9/17/1996 | 8:04 AM | Shepard | 103 | sink | 1 | 0.04 | 0.33 | 1996 |
| 9/17/1996 | 8:05 AM | Shepard | 208A | df | 5 | 0.15 | 2.30 | 1996 |

OSU Drinking Water Sampling Results - 1988:2005

9/7/2016

During sampling, if the EPA action level was exceeded for lead, mandatory repairs were typically made to the water supply system (replacing piping and/or fixtures). NT = not tested. ND = not detected

Action level or maximum contaminant level

15

1.3

0.3

| Date | Time | Building | Room/ Location | Source | Lead (ug/L) | Copper (mg/L) | Iron (mg/L) | year |
|------------|---------|-----------------|----------------|--------|-------------|---------------|-------------|------|
| 7/30/2004 | | Shepard | 208A | DF | NT | 0.14 | 2.34 | 2004 |
| 9/25/1996 | 7:30 AM | Snell | 010 | df | 0 | 0.11 | 0.06 | 1996 |
| 9/25/1996 | 7:32 AM | Snell | 020 | sink | 0 | 0.12 | 0.05 | 1996 |
| 9/25/1996 | 7:12 AM | Snell | 120 | df | 0 | 0.16 | 0.07 | 1996 |
| 9/25/1996 | 7:13 AM | Snell | 124 | sink | 3 | 0.61 | 0.01 | 1996 |
| 8/30/1994 | 0745 | snell | 143 | df | 1.0 | 0.920 | 0.390 | 1994 |
| 9/25/1996 | 7:11 AM | Snell | 143 | df | 0 | 1.42 | 0.10 | 1996 |
| 9/25/1996 | 7:12 AM | Snell | 149 | sink | 0 | 0.53 | 0.01 | 1996 |
| 9/25/1996 | 7:15 AM | Snell | 221 | df | 0 | 0.11 | 0.56 | 1996 |
| 9/25/1996 | 7:20 AM | Snell | 241 | sink | 1 | 0.91 | 0.01 | 1996 |
| 9/25/1996 | 7:25 AM | Snell | 310 | df | 0 | 0.11 | 0.01 | 1996 |
| 8/30/1994 | 0741 | snell | 325 | si | 0.1 | 0.620 | 0.010 | 1994 |
| 9/25/1996 | 7:22 AM | Snell | 325 | sink | 0 | 0.73 | 0.01 | 1996 |
| 9/25/1996 | 7:25 AM | Snell | 337 | df | 0 | 0.13 | 0.09 | 1996 |
| 9/25/1996 | 7:20 AM | Snell | 410 | df | 1 | 0.28 | 0.01 | 1996 |
| 9/25/1996 | 7:19 AM | Snell | 434 | df | 0 | 0.13 | 0.07 | 1996 |
| 8/30/1994 | 0739 | snell | 446 | si | 0.1 | 0.340 | 0.010 | 1994 |
| 9/25/1996 | 7:17 AM | Snell | 446 | sink | 0 | 0.18 | 0.01 | 1996 |
| 9/25/1996 | 7:09 AM | Snell | 515 | sink | 0 | 0.30 | 0.00 | 1996 |
| 9/25/1996 | 7:13 AM | Snell | 520 | df | 0 | 0.21 | 0.20 | 1996 |
| 9/25/1996 | 7:11 AM | Snell | 540 | df | 0 | 0.27 | 0.01 | 1996 |
| 8/23/1994 | 0816 | Social Science | 104 | df | 9.0 | 0.400 | 0.300 | 1994 |
| 12/13/1994 | 0630 | Social Science | 104 | df | 8.0 | NT | NT | 1994 |
| 1995 | -- | Social Science | 104 | DF | 5 | 0.49 | 0.28 | 1995 |
| 12/13/1994 | 0640 | Social Science | 202 | si | 12.0 | NT | NT | 1994 |
| 12/13/1994 | 0634 | Social Science | 205 | df | 7.0 | NT | NT | 1994 |
| 1995 | -- | Social Science | 205 | DF | 1 | 0.73 | 0.19 | 1995 |
| 8/23/1994 | 0822 | Social Science | 303 | df | 25.0 | 0.370 | 0.440 | 1994 |
| 12/13/1994 | 0635 | Social Science | 303 | df | 11.0 | 0.000 | NT | 1994 |
| 1995 | -- | Social Science | 303 | SI | 3 | 0.77 | 0.47 | 1995 |
| 1995 | -- | Social Science | 305 | DF | 8 | 0.48 | 0.2 | 1995 |
| 9/26/1996 | 8:00 AM | Strand | 032 | sink | 1 | 0.01 | 0.11 | 1996 |
| 7/29/2004 | | Strand | 032 | Sink | NT | 0.02 | 0.97 | 2004 |
| 9/26/1996 | 7:56 AM | Strand | 033 | df | 1 | 0.03 | 0.15 | 1996 |
| 2/15/2004 | -- | Strand | 033 | DF | NT | 0.01 | 0.01 | 2004 |
| 7/29/2004 | | Strand | 033 | DF | NT | 0.15 | 0.18 | 2004 |
| 8/23/1991 | 0803 | strand | 112 | df | 1.0 | 1.340 | 0.330 | 1991 |
| 9/26/1996 | 7:28 AM | Strand | 112A | df | 1 | 0.71 | 0.32 | 1996 |
| 2/15/2004 | -- | Strand | 112A | DF | NT | 0.06 | 0.24 | 2004 |
| 7/29/2004 | | Strand | 112A | DF | NT | 0.32 | 0.13 | 2004 |
| 9/26/1996 | 7:40 AM | Strand | 136A | sink | 1 | 0.27 | 0.21 | 1996 |
| 7/29/2004 | | Strand | 136A | Sink | NT | 0.05 | 0.17 | 2004 |
| 9/26/1996 | 7:46 AM | Strand | 201 | sink | 0 | 0.02 | 0.68 | 1996 |
| 7/29/2004 | | Strand | 201 | Sink | NT | 0.01 | 0.46 | 2004 |
| 9/26/1996 | 7:42 AM | Strand | 219 | df | 1 | 0.14 | 1.99 | 1996 |
| 7/29/2004 | | Strand | 219 | DF | NT | 0.02 | 0.33 | 2004 |
| 2/15/2004 | -- | Strand | 219 | DF | NT | 0.03 | 0.09 | 2004 |
| 9/26/1996 | 7:52 AM | Strand | 303 | sink | 2 | 0.03 | 0.61 | 1996 |
| 7/29/2004 | | Strand | 303 | Sink | NT | 0.01 | 0.55 | 2004 |
| 8/23/1994 | 0809 | strand | 321 | df | 7.0 | 0.010 | 0.720 | 1994 |
| 9/26/1996 | 7:44 AM | Strand | 321 | df | 1 | 0.10 | 1.77 | 1996 |
| 7/29/2004 | | Strand | 321 | DF | NT | 0.12 | 0.01 | 2004 |
| 9/26/1996 | 7:48 AM | Strand | 327 | sink | 1 | 0.02 | 0.45 | 1996 |
| 10/12/1994 | 0650 | surplus | 103 | df | 9.0 | 0.400 | 0.840 | 1994 |
| 12/22/1998 | 7:04 | Valley football | 118 | DF | 0 | 2.63 | 0.01 | 1998 |
| 12/22/1999 | -- | Valley football | 118 | DF | 1 | 2.25 | 0.01 | 1999 |

OSU Drinking Water Sampling Results - 1988:2005

9/7/2016

During sampling, if the EPA action level was exceeded for lead, mandatory repairs were typically made to the water supply system (replacing piping and/or fixtures). NT = not tested. ND = not detected

Action level or maximum contaminant level

15 1.3 0.3

| Date | Time | Building | Room/ Location | Source | Lead (ug/L) | Copper (mg/L) | Iron (mg/L) | year |
|------------|---------|------------------|------------------|--------|-------------|---------------|-------------|------|
| 12/30/1999 | -- | Valley football | 126 | Sink | 0 | 0.58 | 0.01 | 1999 |
| 12/22/1999 | -- | Valley football | 132 | DF | 1 | 2.17 | 0.01 | 1999 |
| 12/30/1999 | -- | Valley football | 202 | DF | 1 | 2.61 | 0.02 | 1999 |
| 12/22/1998 | 7:09 | Valley football | 206B | DF | 0 | 1.68 | 0.01 | 1998 |
| 12/30/1999 | -- | Valley football | 209 | DF | 0 | 0.50 | 0.01 | 1999 |
| 12/22/1998 | 7:07 | Valley football | 211 | DF | 0 | 0.43 | 0.01 | 1998 |
| 10/12/1994 | 0807 | Valley football | 301 | df | 0.1 | 1.510 | 0.010 | 1994 |
| 12/22/1998 | 7:12 | Valley football | 311 | sink | 1 | 1.25 | 0.01 | 1998 |
| 12/22/1998 | 7:19 | Valley football | 336 | sink | 28 | 1.74 | 0.01 | 1998 |
| 12/30/1999 | -- | Valley football | 336 | Sink | 1 | 2.36 | 0.02 | 1999 |
| 12/22/1999 | -- | Valley football | 3rd fl MRR | DF | 1 | 1.32 | 0.01 | 1999 |
| 12/22/1998 | 7:15 | Valley football | 3rd flr men's rm | DF | 0 | 1.82 | 0.01 | 1998 |
| 12/23/1998 | 7:32 | Valley Library | 1085 | DF | 11 | 1.38 | 0.02 | 1998 |
| 12/23/1998 | 7:27 | Valley Library | 1565 | DF | 0 | 1.08 | 0.01 | 1998 |
| 12/23/1998 | 7:23 | Valley Library | 2566 | DF | 0 | 1.15 | 0.01 | 1998 |
| 12/23/1998 | 7:21 | Valley Library | 3000 | sink | 0 | 0.67 | 0.02 | 1998 |
| 12/23/1998 | 7:20 | Valley Library | 3565 | DF | 0 | 1.35 | 0.01 | 1998 |
| 12/23/1998 | 7:11 | Valley Library | 4065 | sink | 0 | 1.77 | 0.01 | 1998 |
| 12/23/1998 | 7:12 | Valley Library | 4566 | DF | 0 | 1.41 | 0.01 | 1998 |
| 12/23/1998 | 7:12 | Valley Library | 4761 | sink | 30 | 1.30 | 0.01 | 1998 |
| 12/23/1998 | 7:16 | Valley Library | 5000 | sink | 25 | 1.63 | 0.01 | 1998 |
| 12/23/1998 | 7:35 | Valley Library | 6566 | DF | 0 | 1.54 | 0.01 | 1998 |
| 8/28/1994 | 1016 | Vet Research Lab | 117 | df | 10.0 | 0.700 | 0.850 | 1994 |
| 1995 | -- | Vet Research Lab | 119 | DF | 1 | 0.97 | 0.72 | 1905 |
| 1995 | -- | Vet Research Lab | 124 | SI | 7 | 0.19 | 2.47 | 1905 |
| 1995 | -- | VMAIL | 106 | DF | 1 | 0.06 | 0.11 | 1905 |
| 1995 | -- | VMAIL | 112 | SI | 1 | 0.16 | 0.14 | 1905 |
| 12/30/1999 | -- | VRL | 116 | DF | 1 | 1.75 | 0.02 | 1999 |
| 9/26/1996 | 7:32 AM | Waldo | 103 | sink | 0 | 0.44 | 0.00 | 1996 |
| 9/26/1996 | 7:29 AM | Waldo | 121A | df | 1 | 1.03 | 0.09 | 1996 |
| 7/29/2004 | | Waldo | 121A | DF | NT | 0.68 | 0.01 | 2004 |
| 9/26/1996 | 7:26 AM | Waldo | 205 | sink | 0 | 0.49 | 0.00 | 1996 |
| 7/29/2004 | | Waldo | 205 | Sink | NT | 0.25 | 0.01 | 2004 |
| 11/7/1988 | 8:00 AM | Waldo | 224 | sink | 9 | 1.99 | 0.046 | 1988 |
| 8/30/1994 | 0749 | waldo | 244 | df | 0.1 | 0.370 | 0.010 | 1994 |
| 9/26/1996 | 7:27 AM | Waldo | 244 | df | 0 | 0.34 | 0.00 | 1996 |
| 7/29/2004 | | Waldo | 244 | DF | NT | 0.24 | 0.01 | 2004 |
| 9/26/1996 | 7:20 AM | Waldo | 320 | sink | 11 | 0.04 | 0.70 | 1996 |
| 7/29/2004 | | Waldo | 320 | Sink | NT | 0.01 | 0.28 | 2004 |
| 9/26/1996 | 7:21 AM | Waldo | 331A | sink | 4 | 0.01 | 0.01 | 1996 |
| 7/29/2004 | | Waldo | 331A | Sink | NT | 0.02 | 2.02 | 2004 |
| 11/7/1988 | 8:02 AM | Waldo | 349 | DF | 5 | 2.2 | 0.316 | 1988 |
| 8/30/1994 | 0752 | waldo | 349 | df | 0.1 | 1.100 | 0.010 | 1994 |
| 9/26/1996 | 7:20 AM | Waldo | 349 | df | 0 | 0.46 | 0.00 | 1996 |
| 7/29/2004 | | Waldo | 349 | df | NT | 0.65 | 0.01 | 2004 |
| 8/25/1994 | 0639 | Weniger | 123 | df | 9.0 | 0.270 | 0.090 | 1994 |
| 12/13/1994 | 1110 | Weniger | 123 | df | 5.0 | NT | NT | 1994 |
| 1995 | -- | Weniger | 123 | DF | 2 | 0.24 | 0.01 | 1905 |
| 1/7/2000 | -- | Weniger | 123 | DF | 0 | 2.06 | 0.01 | 2000 |
| 12/14/1994 | 0700 | Weniger | 136 | df | 1.0 | NT | NT | 1994 |
| 1995 | -- | Weniger | 136 | DF | 3 | 0.31 | 0.26 | 1905 |
| 1/7/2000 | -- | Weniger | 136 | DF | 0 | 0.96 | 0.01 | 2000 |
| 12/14/1994 | 0701 | Weniger | 145 | df | 1.0 | NT | NT | 1994 |
| 1995 | -- | Weniger | 145 | DF | 1 | 0.05 | 0.4 | 1905 |
| 1/7/2000 | -- | Weniger | 145 | DF | 0 | 0.38 | 0.01 | 2000 |
| 1995 | -- | Weniger | 211 | DF | 1 | 1.14 | >3.30 | 1905 |

OSU Drinking Water Sampling Results - 1988:2005

9/7/2016

During sampling, if the EPA action level was exceeded for lead, mandatory repairs were typically made to the water supply system (replacing piping and/or fixtures). NT = not tested. ND = not detected

Action level or maximum contaminant level

15

1.3

0.3

| Date | Time | Building | Room/ Location | Source | Lead (ug/L) | Copper (mg/L) | Iron (mg/L) | year |
|------------|------|-----------------|----------------|---------|-------------|---------------|-------------|------|
| 12/14/1994 | 0710 | Weniger | 211A | df | 0.1 | NT | NT | 1994 |
| 1/7/2000 | -- | Weniger | 211A | DF | 0 | 0.71 | 0.01 | 2000 |
| 12/13/1994 | 1115 | Weniger | 231 | df | 3.0 | NT | NT | 1994 |
| 1995 | -- | Weniger | 231 | DF | 4 | 0.23 | 0.05 | 1995 |
| 1/7/2000 | -- | Weniger | 231 | DF | 0 | 1.5 | 0.02 | 2000 |
| 12/14/1994 | 0705 | Weniger | 253 | df | 6.0 | NT | NT | 1994 |
| 1995 | -- | Weniger | 253 | DF | 1 | 0.24 | 0.33 | 1995 |
| 1/7/2000 | -- | Weniger | 253 | DF | 1 | 1.23 | 0.01 | 2000 |
| 1995 | -- | Weniger | 307 | DF | 0 | 2.01 | >3.30 | 1995 |
| 12/14/1994 | 0708 | Weniger | 307A | df | 0.1 | NT | NT | 1994 |
| 1/7/2000 | -- | Weniger | 307A | DF | 0 | 0.70 | 0.02 | 2000 |
| 12/13/1994 | 1120 | Weniger | 327 | df | 2.0 | NT | NT | 1994 |
| 1995 | -- | Weniger | 327 | DF | 3 | 0.25 | 0.05 | 1995 |
| 1/7/2000 | -- | Weniger | 327 | DF | 0 | 2.03 | 0.02 | 2000 |
| 8/23/1994 | 0850 | Weniger | 351 | df | 17.0 | 0.460 | 0.510 | 1994 |
| 12/13/1994 | 1050 | Weniger | 351 | df | 1.0 | NT | NT | 1994 |
| 1995 | -- | Weniger | 351 | DF | 1 | 0.33 | 0.25 | 1995 |
| 1/7/2000 | -- | Weniger | 351 | DF | 0 | 1.03 | 0.01 | 2000 |
| 1995 | -- | Weniger | 385 | SI | 1 | 0.03 | 0.05 | 1995 |
| 1995 | -- | Weniger | 407 | DF | 0 | 2.27 | >3.30 | 1995 |
| 12/13/1994 | 1105 | Weniger | 407A | df | 1.0 | NT | NT | 1994 |
| 1/7/2000 | -- | Weniger | 407A | DF | 1 | 1.19 | 0.01 | 2000 |
| 12/14/1994 | 0715 | Weniger | 427 | df | 1.0 | NT | NT | 1994 |
| 1995 | -- | Weniger | 427 | DF | 1 | 0.56 | 0.01 | 1995 |
| 1/7/2000 | -- | Weniger | 427 | DF | 1 | 1.39 | 0.01 | 2000 |
| 12/14/1994 | 0720 | Weniger | 459 | df | 2.0 | NT | NT | 1994 |
| 1995 | -- | Weniger | 459 | DF | 0 | 0.38 | 0.25 | 1995 |
| 1995 | -- | Weniger | 505 | DF | 0 | 1.18 | >3.30 | 1995 |
| 12/14/1994 | 0716 | Weniger | 505A | df | 0.1 | NT | NT | 1994 |
| 1/7/2000 | -- | Weniger | 505A | DF | 0 | 0.99 | 0.04 | 2000 |
| 12/14/1994 | 0725 | Weniger | 517 | df | 1.0 | NT | NT | 1994 |
| 1995 | -- | Weniger | 517 | DF | 3 | 0.58 | 0.01 | 1995 |
| 1/7/2000 | -- | Weniger | 517 | DF | 0 | 1.43 | 0.01 | 2000 |
| 12/13/1994 | 1101 | Weniger | 539 | df | 1.0 | NT | NT | 1994 |
| 1995 | -- | Weniger | 539 | DF | 2 | 0.59 | 0.45 | 1995 |
| 1/7/2000 | -- | Weniger | 539 | DF | 0 | 1.53 | 0.01 | 2000 |
| 8/25/1994 | 0838 | Weniger | 631 | df | 8.0 | 0.660 | 0.210 | 1994 |
| 12/13/1994 | 1100 | Weniger | 631 | df | 25.0 | NT | NT | 1994 |
| 1995 | -- | Weniger | 631 | DF | 2 | 1.08 | 0.16 | 1995 |
| 1/7/2000 | -- | Weniger | 631 | DF | 1 | 0.15 | 0.04 | 2000 |
| 1995 | -- | West Dining | 100 | DF hot | 0 | 0.1 | 0.15 | 1995 |
| 1995 | -- | West Dining | 100 | DF cold | 1 | 0.23 | 0.38 | 1995 |
| 1995 | -- | West Dining | 100 | SI | 1 | 0.08 | 0.96 | 1995 |
| 9/28/1994 | 0732 | West Greenhouse | 009 | df | 1.0 | 1.590 | 0.020 | 1994 |
| 9/28/1994 | 0728 | West Greenhouse | 014 | df | 1.0 | 1.480 | 0.010 | 1994 |
| 1995 | -- | West Greenhouse | 14-1 | DF | 0 | 2.23 | 0.01 | 1995 |
| 1995 | -- | West Greenhouse | 14-1 | SI | 5 | 0.52 | 0.04 | 1995 |
| 1995 | -- | West Greenhouse | 9-1 | DF | 1 | 1.88 | 0.01 | 1995 |
| 1995 | -- | West Greenhouse | residence | SI | 0 | 0.39 | 0.01 | 1995 |
| 1995 | -- | Western Av 221 | 100 | SI | 1 | 0.13 | 0.3 | 1995 |
| 1995 | -- | Western Av 222 | 104 | SI | 3 | 0.01 | 0.29 | 1995 |
| 1995 | -- | Western Av 223 | 100 | SI | 12 | 0.03 | 0.28 | 1995 |
| 1995 | -- | Western Av 224 | 100C | SI | 1 | 0.53 | 0.04 | 1995 |
| 1995 | -- | Western Av 225 | 105 | SI | 0 | 0.51 | 0.7 | 1995 |
| 10/5/1994 | 0755 | Western Av 226 | 102 | si | 1.0 | 0.040 | 0.140 | 1994 |
| 1995 | -- | Western Av 226 | 102 | SI | 1 | 0.25 | 0.22 | 1995 |

OSU Drinking Water Sampling Results - 1988:2005

9/7/2016

During sampling, if the EPA action level was exceeded for lead, mandatory repairs were typically made to the water supply system (replacing piping and/or fixtures). NT = not tested. ND = not detected

| Action level or maximum contaminant level | | | | | 15 | 1.3 | 0.3 | |
|---|------|----------------|----------------|----------|-------------|---------------|-------------|------|
| Date | Time | Building | Room/ Location | Source | Lead (ug/L) | Copper (mg/L) | Iron (mg/L) | year |
| 10/5/1994 | 0747 | Western Av 227 | 104 | si | 1.0 | 0.210 | 0.010 | 1994 |
| 1995 | -- | Western Av 227 | 104 | SI | 0 | 0.18 | 0.01 | 1905 |
| 9/28/1994 | 0740 | Wiegand | 103 | df | 11.0 | 0.170 | 0.170 | 1994 |
| 12/16/1998 | 7:02 | Wiegand | 103 | DF | 1 | 1.03 | 0.01 | 1998 |
| 12/16/1998 | 7:03 | Wiegand | 119 | DF | 0 | 0.54 | 0.02 | 1998 |
| 9/28/1994 | 0742 | wiegand | 211 | df | 2.0 | 0.340 | 0.570 | 1994 |
| 12/16/1998 | 7:02 | Wiegand | 211 | DF | 0 | 1.72 | 0.02 | 1998 |
| 12/16/1998 | 7:00 | Wiegand | 212 | sink | 0 | 1.81 | 0.02 | 1998 |
| 12/16/1998 | 7:05 | Wiegand | 225 | DF | 1 | 1.74 | 0.12 | 1998 |
| 1995 | -- | Wilkinson | 007 | DF | 1 | 0.24 | 0.17 | 1905 |
| 12/16/1994 | 0720 | Wilkinson | 007 | df | 1.0 | 0.120 | 0.040 | 1994 |
| 1/12/2000 | -- | Wilkinson | 007 | DF | 1 | 0.09 | 1.19 | 2000 |
| 1995 | -- | Wilkinson | 031 | DF | 8 | 0.21 | 0.27 | 1905 |
| 12/16/1994 | 0716 | Wilkinson | 031 | df | 11.0 | 0.230 | 0.470 | 1994 |
| 1/12/2000 | -- | Wilkinson | 031 | DF | 10 | 0.21 | 0.23 | 2000 |
| 1995 | -- | Wilkinson | 102E | SI | 3 | 0.01 | 0.06 | 1905 |
| 1/12/2000 | -- | Wilkinson | 102E | Sink | 1 | 0.03 | 0.17 | 2000 |
| 8/30/1994 | 0910 | Wilkinson | 103 | df | 1.0 | 0.100 | 0.180 | 1994 |
| 12/16/1994 | 0711 | Wilkinson | 103 | df | 7.0 | 0.100 | 0.330 | 1994 |
| 1/12/2000 | -- | Wilkinson | 103 | DF | 3 | 0.06 | 0.26 | 2000 |
| 1995 | -- | Wilkinson | 104 | DF | 1 | 0.15 | 0.08 | 1905 |
| 1995 | -- | Wilkinson | 110 | SI | 3 | 1.06 | 0.37 | 1905 |
| 12/16/1994 | 0705 | Wilkinson | 129 | df | 3.0 | 0.130 | 0.170 | 1994 |
| 1/12/2000 | -- | Wilkinson | 129 | DF | 12 | 0.13 | 0.58 | 2000 |
| 1995 | -- | Wilkinson | 130 | DF | 1 | 0.23 | 0.48 | 1905 |
| 1995 | -- | Wilkinson | 206 | DF | 2 | 0.16 | 0.31 | 1905 |
| 12/16/1994 | 0714 | Wilkinson | 207 | df | 8.0 | 0.140 | 0.470 | 1994 |
| 1/12/2000 | -- | Wilkinson | 207 | DF | 1 | 0.15 | 0.37 | 2000 |
| 1/12/2000 | -- | Wilkinson | 208 | | 7 | 0.04 | 0.85 | 2000 |
| 8/30/1994 | 0912 | Wilkinson | 233 | df | 23.0 | 0.330 | 0.340 | 1994 |
| 12/16/1994 | 0713 | Wilkinson | 233 | df | 16.0 | 0.390 | 0.410 | 1994 |
| 1/12/2000 | -- | Wilkinson | 235 | DF | 2 | 0.13 | 0.17 | 2000 |
| 1995 | -- | Wilkinson | 236 | DF | 6 | 0.06 | 0.25 | 1905 |
| 12/16/1998 | 7:25 | Withycombe | 053C | sink | 1 | 0.47 | 0.27 | 1998 |
| 12/16/1998 | 7:15 | Withycombe | 100 | sink | 0 | 0.06 | 0.18 | 1998 |
| 12/16/1998 | 7:20 | Withycombe | 108 | DF | 1 | 1.79 | 0.03 | 1998 |
| 6/11/2004 | -- | Withycombe | 108 | DF | NT | 0.47 | 0.00 | 2004 |
| 6/11/2004 | -- | Withycombe | 117 | Sink | NT | 0.06 | 0.01 | 2004 |
| 12/16/1998 | 7:18 | Withycombe | 130 | DF | 1 | 1.54 | 2.62 | 1998 |
| 6/11/2004 | -- | Withycombe | 130 | DF | NT | 0.42 | 0.16 | 2004 |
| 9/28/1994 | 0717 | withycombe | 135 | df | 1.0 | 1.130 | 0.480 | 1994 |
| 6/11/2004 | -- | Withycombe | 145 | DF | NT | 0.75 | 0.14 | 2004 |
| 12/16/1998 | 7:20 | Withycombe | 151 | DF | 0 | 1.02 | 0.02 | 1998 |
| 6/11/2004 | -- | Withycombe | 201 | Sink | NT | 0.65 | 0.00 | 2004 |
| 6/11/2004 | -- | Withycombe | 213 | DF | NT | 0.14 | 0.05 | 2004 |
| 9/28/1994 | 0720 | withycombe | 303 | df | 1.0 | 0.740 | 0.920 | 1994 |
| 12/16/1998 | 7:22 | Withycombe | 308 | DF | 18 | 0.59 | 3.06 | 1998 |
| 6/11/2004 | -- | Withycombe | 308 | DF | NT | 0.67 | 0.16 | 2004 |
| 11/19/2000 | -- | Wmns bldg | 011A | standing | NT | 1.29 | NT | 2000 |
| 11/19/2000 | -- | Wmns bldg | 011A | running | NT | 0.16 | NT | 2000 |
| 8/30/1994 | 0842 | Wmns bldg | 025 | df | 1.0 | 0.680 | 0.020 | 1994 |
| 12/21/1998 | 7:00 | Wmns bldg | 111 | DF | 0 | 0.66 | 0.08 | 1998 |
| 12/21/1998 | 7:00 | Wmns bldg | 112N | DF | 1 | 1.51 | 0.01 | 1998 |
| 12/21/1998 | 7:00 | Wmns bldg | 112S | DF | 2 | 1.02 | 0.03 | 1998 |
| 12/21/1998 | 6:58 | Wmns bldg | 124 | SDF | 5 | 0.99 | 0.01 | 1998 |
| 8/30/1994 | 0844 | Wmns bldg | 210 | df | 0.1 | 1.740 | 0.010 | 1994 |

OSU Drinking Water Sampling Results - 1988:2005

9/7/2016

During sampling, if the EPA action level was exceeded for lead, mandatory repairs were typically made to the water supply system (replacing piping and/or fixtures). NT = not tested. ND = not detected

Action level or maximum contaminant level

15

1.3

0.3

| Date | Time | Building | Room/ Location | Source | Lead (ug/L) | Copper (mg/L) | Iron (mg/L) | year |
|------------|------|-----------|-------------------|--------|----------------|------------------|----------------|------|
| 12/21/1998 | 6:56 | Wmns bldg | 210 | DF | 1 | 2.16 | 0.01 | 1998 |
| 12/21/1998 | 6:55 | Wmns bldg | 210A | sink | 1 | 1.39 | 0.01 | 1998 |